Indian Point 3 Nuclear Power Plant P.O. Box 215 Buchanan, New York 10511 914 739.8200



New York Power Authority

April 1, 1991 IP3-91-023 IP3-91-014W

Docket No. 50-286 License No. DPR-64

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Mail Station PI-137 Washington, D.C. 20555

Dear Sir:

Enclosed you will find the monthly operating report relating to Indian Point 3 Nuclear Power Plant for the month of March 1991.

IE24

Verv truly yours Une

Jogeph E. Russell Resident Manager Indian Point 3 Nuclear Power Plant

JER:SS:JB:sd:MOR.06

Enclosure

cc: Mr. Thomas T. Martin, Regional Administrator Region 1 U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

INPO Records Center Suite 1500 1100 Circle 75 Parkway Atlanta, Georgia 30339



OPERATING DATA REPORT

Docket No.	<u>50-286</u>
Date	04-01-91
Completed By	L. Kelly
Telephone	914 736-8340
-	

OPERATING STATUS

			noces	
1.	Unit Name: <u>Indian Point No. 3 Nuclear</u>	<u>Power Plant</u>		,
2.	Reporting Period: <u>March 1991</u>			
3.	Licensed Thermal Power (MWt):3025	· · · · · · · · · · · · · · · · · · ·		
4.	Nameplate Rating (Gross MWe): 1013			
5.	Design Electrical Rating (Net MWe):	965		
6	Maximum Dependable Canacity (Gross MWe)	: 1000		
7	Maximum Dependable Capacity (Not MWo):	. 1000		
· ·	If Changes Occur in Canadity Ratings (I	tome Number	2 through 7)	Sindo Tact
0.	Depart Give Descende		5 chrough 7	SINCE LAST
	Report. Give Reasons:			
0	Dover Level to Which Destricted If Any	(Not MUO) .	· · · · · · · · · · · · · · · · · · ·	· · · · ·
9.	Power Level to which Restricted, 11 Any	(Net Mwe):		
10.	Reasons for Restrictions, if Any:			
	<u> </u>			
	· · · · · · · · · · · · · · · · · · ·			
		This Month	Vr to Date	Cumulativo
1 1	Hours In Donorting Doried		2160	
11.	Number of House Decetor Mag Critical		2100	70 454 10
12.	Number of Hours Reactor was critical			
13.	Reactor Reserve Shutdown Hours	0	0	0
14.	Hours Generator On-Line	478.64	1894.64	77,234.39
15.	Unit Reserve Shutdown Hours	0	0	0
16.	Gross Thermal Energy Generated (MWH)	<u>1,420,780</u>	<u> 5,503,889</u>	<u>218,750,423</u>
17.	Gross Electrical Energy Generated (MWH)	482,310	<u>1,866,150</u>	<u>67,529,035</u>
18.	Net Electrical Generated (MWH)	467,069	1,805,788	64,909,004
19.	Unit Service Factor	64.3	87.7	60.4**
20.	Unit Availability Factor	64.3	87.7	60.4**
21.	Unit Capacity Factor (Using MDC Net)	65.1	86.6	54.1 *
22.	Unit Capacity Factor (Using DER Net)	65.1	86.6	52.6**
23.	Unit Forced Outage Rate	35.7	12.3	16.0
24.	Shutdowns Scheduled Over Next 6 Months(Type.Date.ar	d Duration of	of Each):
	* Weighted Average	-16-1	· · · · · · · · · · · · · · · · · · ·	,
	** Reflects a 360 hour correction from	September 1	990	
25.	If Shut Down At End Of Report Period. E	stimated Dat	e of Startur	April 1991
			<u>-</u>	····
26.	Units In Test Status (Prior to Commerci	al Operatior	n):	, ,,, , , ,
		For	ocast	Achieved
		IUI		1101170400
	ΤΝΤΠΤΑΙ ΟΡΤΠΙΟΙΙΤΟΥ		с. С	
	INITIAL CRITICALITY			·····
	INITIAL ELECTRICITY			

COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	50-286
UNIT	IP-3
DATE	04-01-91
COMPLETED BY	L. Kelly
TELEPHONE	(914) 736-8340

MONT	H <u>MARCH 1991</u>	-			
DAY	AVERAGE DAILY POWER LE (MWe-Net)	EVEL		DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	993			17	980
2	965	<u> </u>		18	988
3	969			19	994
4	981			20	800
5	981		•	21	0
6	983			22	12
7	982	·		23	0
8	980			24	O
9	982	•		25	. <u>O</u>
10	980			26	0
11	981		· ·	27	O
12	981	·		28	O
13	981			29	O
14	983			30	0
15	983			31	0
16	981				

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

50-286
INDIAN POINT NO. 3
04-01-91
L. Kelly
(914) 736-8340
•

REPORT MONTH <u>MARCH 1991</u>

.

							.		· · · · · · · · · · · · · · · · · · ·
NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE Event Report #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
1	910320	F	33.87	A	3	91-005-00	xx	xxxxxx	AUTOMATIC SHUTDOWN DUE TO A DIRECT ELECTRICAL TRIP FROM THE BUCHANAN SUBSTATION.
2	910322	F	19.69		3	91-006-00	СН	VALVEX C	AUTOMATIC SHUTDOWN DUE TO LOW STEAM GENERATOR LEVEL CAUSED BY THE
									FAILURE OF MAIN BOILER FEED PUMP (MBFP) DISCHARGE CHECK VALVE BFD-1-1 ASSOCIATED WITH NO.
				· •					31 MBFP.
3	910323	F	211.80	A	1	91-007-00	HA	TURBIN	MANUALLY SECURED TURBINE GENERATOR DUE TO HIGH INDICATED VIBRATIONS ON TURBINE BEARINGS.
1 F: S:	Forced Scheduled	2 R I A B C D	eason: -Equipment -Maintenanc -Refueling - Regulator	e or Tes y Restri	3 Met 1-N t 2-N 3-Z ction 4-C	chod Manual Manual Scram Mutomatic Sc Other (Expla	4 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Exhibit - In For Preparat Entry Sheets Event Report ()161)	structions ion of Data for Licensee (LER) File (NUREG-

5 Exhibit - Same Source

SUMMARY OF OPERATING EXPERIENCE

MARCH 1991

Indian Point Unit No. 3 was synchronized to the bus for a total of 478.64 hours, producing a gross generation of 482,410 MWe.

On March 20, at 1915 hours, the plant was automatically shutdown due to a direct electrical "trip" casued by a fault from the Buchanan Substation. The fault was caused by 345 Kv Bus Section 3 Phase 3 PT Failure. The plant was stabilized in the hot shutdown condition while an investigation and repairs were performed.

After repairs were made, the Reactor was brought critical on March 21, at 2043 hours. The unit was synchronized to the bus on March 22, at 0507 hours. At 0814 hours, the unit was automatically shutdown due to low level in No. 32 Steam Generator. This was the result of the failure of a Main Boiler Feed Pump (MBFP) discharge check valve BFD-1-1 associated with No. 31 MBFP. After repairs were made the Reactor was brought critical at 1950 hours.

On March 23, at 0356 hours, the unit was synchronized to the bus. At 0412 hours, the turbine was manually secured due to high indicated vibrations on Low Pressure Turbine Bearings No.'s 5 and 6. On March 24, at 0210 hours, the Reactor was manually secured. On March 25, at 0900 hours, the unit began to proceed to the cold shutdown condition for an unscheduled turbine maintenance outage. Cold shutdown was reached on March 26, at 0330 hours, and the unit remained off the line for the remainder of the reporting period.