

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



Joseph E. Russell
Resident Manager

October 7, 1991
IP-NRC-91-060

Docket No. 50-286
License No. DPR-64

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station PI-137
Washington, D.C. 20555

Dear Sir:

Enclosed you will find the monthly operating report relating to Indian Point 3 Nuclear Power Plant for the month of September 1991.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'J. Russell'.

Joseph E. Russell
Resident Manager
Indian Point 3 Nuclear Power Plant


JER:dc

Enclosure

cc: Mr. Thomas T. Martin, Regional Administrator
Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

150610



IF24
11

OPERATING DATA REPORT

Docket No. 50-286
 Date 10-01-91
 Completed By L. Kelly
 Telephone 914 736-8340

OPERATING STATUS

Notes

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: September 1991
3. Licensed Thermal Power (MWt): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 1000
7. Maximum Dependable Capacity (Net MWe): 965
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report. Give Reasons: _____
9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons for Restrictions, If Any: _____

	This Month	Yr. to Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>6551</u>	<u>132,240</u>
12. Number of Hours Reactor Was Critical	<u>720</u>	<u>5840.45</u>	<u>83,361.54</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>720</u>	<u>5760.85</u>	<u>81,100.6</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,177,938</u>	<u>16,929,634</u>	<u>230,176,168</u>
17. Gross Electrical Energy Generated (MWH)	<u>732,320</u>	<u>5,711,160</u>	<u>71,374,045</u>
18. Net Electrical Generated (MWH)	<u>706,260</u>	<u>5,515,218</u>	<u>68,647,851</u>
19. Unit Service Factor	<u>100</u>	<u>87.9</u>	<u>61.3</u>
20. Unit Availability Factor	<u>100</u>	<u>87.9</u>	<u>61.3</u>
21. Unit Capacity Factor (Using MDC Net)	<u>101.6</u>	<u>87.2</u>	<u>55.2 *</u>
22. Unit Capacity Factor (Using DER Net)	<u>101.6</u>	<u>87.2</u>	<u>53.7</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>7.8</u>	<u>15.5</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Two (2) month cycle 8/9 refueling outage scheduled to begin March 28, 1992.
 * Weighted Average.

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-286
 UNIT IP-3
 DATE 10-01-91
 COMPLETED BY L. Kelly
 TELEPHONE (914) 736-8340

MONTH SEPTEMBER 1991

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	978
2	980
3	980
4	981
5	979
6	979
7	979
8	979
9	978
10	978
11	978
12	980
13	980
14	981
15	981
16	981

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	979
18	980
19	980
20	983
21	981
22	981
23	982
24	981
25	982
26	983
27	985
28	986
29	985
30	986
31	-

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-286
 UNIT NAME INDIAN POINT NO. 3
 DATE 10-01-91
 COMPLETED BY L. Kelly
 TELEPHONE (914) 736-8340

REPORT MONTH SEPTEMBER 1991

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
	NONE								

1

2

3

4

F: Forced
S: Scheduled

Reason:
 A-Equipment
 B-Maintenance or Test
 C-Refueling
 D- Regulatory Restriction

Method
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

Exhibit - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5 Exhibit - Same Source

SUMMARY OF OPERATING EXPERIENCE

SEPTEMBER 1991

Indian Point Unit No. 3 was synchronized to the bus for a total of 720 hours, producing a gross generation of 732,320 MWe.