

Indian Point 3  
Nuclear Power Plant  
P.O. Box 215  
Buchanan, New York 10511  
914 736.8001



**New York Power  
Authority**

**Joseph E. Russell**  
Resident Manager

February 6, 1992  
IP3-NRC-92-011

Docket No. 50-286  
License No. DPR-64

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station PI-137  
Washington, D.C. 20555

Dear Sir:

Enclosed you will find the monthly operating report relating to Indian Point 3 Nuclear Power Plant for the month of January 1992.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'J. E. Russell', written over the typed name.

Joseph E. Russell  
Resident Manager  
Indian Point 3 Nuclear Power Plant

JER:dc

Enclosure

cc: Mr. Thomas T. Martin, Regional Administrator  
Region 1  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

190007

9202180286 920131  
PDR ADOCK 05000286  
R PDR

IE24  
111

OPERATING DATA REPORT

Docket No. 50-286  
 Date 02-03-92  
 Completed By L. Kelly  
 Telephone (914) 736-8340

OPERATING STATUS

Notes

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: January 1992
3. Licensed Thermal Power (MWT): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 1000
7. Maximum Dependable Capacity (Net MWe): 965
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report. Give Reasons: \_\_\_\_\_
9. Power Level to Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reasons for Restrictions, If Any: \_\_\_\_\_

|  | This Month | Yr. to Date | Cumulative  |
|--|------------|-------------|-------------|
| 11. Hours In Reporting Period  | 744        | 744         | 135,193     |
| 12. Number of Hours Reactor Was Critical   | 744        | 744         | 85,933.54   |
| 13. Reactor Reserve Shutdown Hours   | 0          | 0           | 0           |
| 14. Hours Generator On-Line  | 744        | 744         | 83,663.25   |
| 15. Unit Reserve Shutdown Hours  | 0          | 0           | 0           |
| 16. Gross Thermal Energy Generated (MWH)   | 2,246,649  | 2,246,649   | 237,951,297 |
| 17. Gross Electrical Energy Generated (MWH)  | 761,890    | 761,890     | 73,982,595  |
| 18. Net Electrical Generated (MWH)   | 738,286    | 738,286     | 71,142,273  |
| 19. Unit Service Factor  | 100        | 100         | 62.1        |
| 20. Unit Availability Factor   | 100        | 100         | 62.1        |
| 21. Unit Capacity Factor (Using MDC Net)   | 102.83     | 102.83      | 56.0 *      |
| 22. Unit Capacity Factor (Using DER Net)   | 102.83     | 102.83      | 54.5        |
| 23. Unit Forced Outage Rate  | 0          | 0           | 15.5        |
| 24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):<br><u>Eighty (80) day cycle 8/9 refueling outage scheduled to begin April 18, 1992. * Weighted Average.</u> |            |             |             |

25. If Shut Down At End Of Report Period. Estimated Date of Startup: \_\_\_\_\_

26. Units In Test Status (Prior to Commercial Operation): \_\_\_\_\_

|                      | Forecast | Achieved |
|----------------------|----------|----------|
| INITIAL CRITICALITY  | _____    | _____    |
| INITIAL ELECTRICITY  | _____    | _____    |
| COMMERCIAL OPERATION | _____    | _____    |

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-286  
 UNIT IP-3  
 DATE 02-03-92  
 COMPLETED BY L. Kelly  
 TELEPHONE (914) 736-8340

MONTH JANUARY 1992

| DAY | AVERAGE DAILY POWER LEVEL<br>(MWe-Net) |
|-----|--|
| 1   | 993                                    |
| 2   | 993                                    |
| 3   | 993                                    |
| 4   | 993                                    |
| 5   | 993                                    |
| 6   | 994                                    |
| 7   | 992                                    |
| 8   | 994                                    |
| 9   | 996                                    |
| 10  | 996                                    |
| 11  | 994                                    |
| 12  | 993                                    |
| 13  | 994                                    |
| 14  | 995                                    |
| 15  | 994                                    |
| 16  | 994                                    |

| DAY | AVERAGE DAILY POWER LEVEL<br>(MWe-Net) |
|-----|--|
| 17  | 994                                    |
| 18  | 992                                    |
| 19  | 993                                    |
| 20  | 994                                    |
| 21  | 995                                    |
| 22  | 994                                    |
| 23  | 951                                    |
| 24  | 992                                    |
| 25  | 994                                    |
| 26  | 994                                    |
| 27  | 994                                    |
| 28  | 992                                    |
| 29  | 993                                    |
| 30  | 994                                    |
| 31  | 994                                    |

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

**UNIT SHUTDOWNS AND POWER REDUCTIONS**

DOCKET NO. 50-286  
 UNIT NAME INDIAN POINT NO. 3  
 DATE 02-03-92  
 COMPLETED BY L. Kelly  
 TELEPHONE (914) 736-8340

REPORT MONTH JANUARY 1992

| NO. | DATE   | TYPE<br>1 | DURATION<br>(HOURS) | REASON<br>2 | METHOD<br>OF<br>SHUTTING<br>DOWN<br>REACTOR<br>3 | LICENSEE<br>EVENT<br>REPORT # | SYSTEM<br>CODE<br>4 | COMPONENT<br>CODE<br>5 | CAUSE & CORRECTIVE<br>ACTION TO PREVENT<br>RECURRENCE   |
|-----|--------|-----------|---------------------|-------------|--|-------------------------------|---------------------|------------------------|---|
| 1   | 920123 | F         | N/A                 | A           | N/A  | N/A                           | IC                  | XXXXXX                 | UNIT LOAD REDUCTION DUE TO BLOWN CONTROL POWER FUSE FOR THE 480 VOLT BUS 5A. ALL SAFEGUARDS EQUIPMENT ASSOCIATED WITH BUS 5A WERE DECLARED INOPERABLE. AS PER TECHNICAL SPECIFICATIONS, A FOUR (4) SHUTDOWN WAS REQUIRED. UNIT PROCEEDED TO 760 MWe. AFTER PROBLEMS WERE RESOLVED, THE UNIT RETURNED TO FULL POWER. |

1

2

3

4

**F:** Forced  
**S:** Scheduled

**Reason:**  
 A-Equipment  
 B-Maintenance or Test  
 C-Refueling  
 D- Regulatory Restriction

**Method**  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Other (Explain)

**Exhibit - Instructions**  
 for Preparation of Data  
 Entry Sheets for Licensee  
 Event Report (LER) File (NUREG-  
 0161)

5 Exhibit - Same Source

## SUMMARY OF OPERATING EXPERIENCE

JANUARY 1992

Indian Point Unit No. 3 was synchronized to the bus for a total of 744 hours, producing a gross generation of 761,890 MWe.

On January 23, at 1045 hours, surveillance test 3PT-M13B, REACTOR PROTECTION LOGIC CHANNEL FUNCTIONAL, was being performed. As per the procedure plant operators placed the control switch for valve PCV-1139 in the "TRIP" position. Operators immediately observed that the control lights for No. 32 Auxiliary Boiler Feed Pump (ABFP) extinguished and the "Safeguard Initiation Racks or 480 Volt Switch-Gear Sequence DC Power Failure" alarm annunciated. Also, the "Non-SI Blackout Logic Defeated" light for No. 33 Emergency Diesel Generator (EDG) extinguished.

At 1130 hours, investigation revealed that the control power fuses for the 480 volt Bus 5A DC sequencing circuitry had blown. It was also revealed that because of this failure, the Safeguards Initiation circuit for Bus 5A was affected. All equipment associated with Bus 5A was then declared inoperable, however, it remained available to be loaded manually throughout the event. The cause of the blown fuses was due to a shorted light socket on the "OPEN" indication light No. 32 ABFP local control panel.

At 1256 hours, No.'s 31 and 33 Fan Cooler Units (FCU's) and No. 31 Containment Spray Pump were declared inoperable, and a four (4) hour Technical Specification shutdown was required. A notification of unusual event (NUE) was declared. A reduction in unit load commenced.

At 1430 hours, after the fuses were replaced and successful completion of a retest on PCV-1139, the safeguards equipment was declared operable and the NUE was terminated. Unit load reduction terminated at 760 MWe and load escalation to full power commenced. Full power was achieved at 2000 hours.