

POWER AUTHORITY OF NEW YORK  
PO BOX 215  
BUCHANAN NY 10511



4-027527S358003 12/23/80 ICS IPMTZZ CSP PHAB  
2 9147398200 MGM TDMT BUCHANAN NY 12-23 1235P EST

CENTRAL FLU  
DISTRIBUTION UNIT  
PM 1 08  
U.S. AIRCRAFT  
COMMUNICATION SERVICES  
BRANCH

SD-286

U S NUCLEAR REGULATORY COMMISSION ATTN BOYCE  
H GRIER DIRECTOR  
REGION 1 OFFICE OF INSPECTION AND ENFORCEMENT  
631 PARK AVE  
KING OF PRUSSIA PA 19406

THIS IS A CONFIRMATION COPY OF A PREVIOUSLY PHONE-DELIVERED TELEGRAM

DURING A ROUTINE REVIEW OF THE SURVEILLANCE TEST PROGRAM IT WAS DETERMINED THAT THE SAFETY INJECTION LOGIC CHANNEL TEST FOR TRAIN A (3PT-M14A) AND TRAIN B (3PT-M14B) HAD EXCEEDED THEIR REQUIRED DUE DATES OF 12-19-80 AND 12-20-80 RESPECTIVELY. AT THE TIME OF THIS DETERMINATION TRAIN A TEST (3PT-M14A) HAD BEEN COMPLETED TRAIN B TEST (3PT-M14B) WAS IMMEDIATELY COMMENCED, WITH AFFECTIVE CHANNEL PLACED IN THE TEST MODE FOR THE PERFORMANCE OF THIS TEST REACTOR POWER LEVEL WAS MAINTAINED CONSTANT UNTIL COMPLETION OF THE TEST. THE TESTING WAS COMPLETED AT 2000 HOURS ON 12-22-80.

S S ZULLA PRESIDENT MANAGER POWER AUTHORITY OF THE STATE OF NEW YORK  
INAIDAN POINT 3 NUCLEAR POWER PLANT PO BOX 215 BUCHANAN NY 10511  
PO BOX 215  
BUCHANAN NY 10511

12:34 EST

MGMCOMP

8101270 854

5201 (01/78)