

POWER AUTHORITY OF NEW YORK
PO BOX 215
BUCHANAN NY 10511



4-027527S358003 12/23/80 ICS IPMNTZZ CSP PHAB
2 9147398200 MGM TDMT BUCHANAN NY 12-23 1235P EST

CENTRAL FLU
DISTRIBUTION
UNIT
PM 1 08
U.S. AIRC
MAIL SERVICES
BRANCH

SD-286

U S NUCLEAR REGULATORY COMMISSION ATTN BOYCE
H GRIER DIRECTOR
REGION 1 OFFICE OF INSPECTION AND ENFORCEMENT
631 PARK AVE
KING OF PRUSSIA PA 19406

THIS IS A CONFIRMATION COPY OF A PREVIOUSLY PHONE-DELIVERED TELEGRAM

DURING A ROUTINE REVIEW OF THE SURVEILLANCE TEST PROGRAM IT WAS
DETERMINED THAT THE SAFETY INJECTION LOGIC CHANNEL TEST FOR TRAIN A
(3PT-M14A) AND TRAIN B (3PT-M14B) HAD EXCEEDED THEIR REQUIRED DUE
DATES OF 12-19-80 AND 12-20-80 RESPECTIVELY. AT THE TIME OF THIS
DETERMINATION TRAIN A TEST (3PT-M14A) HAD BEEN COMPLETED TRAIN B TEST
(3PT-M14B) WAS IMMEDIATELY COMMENCED, WITH AFFECTIVE CHANNEL PLACED
IN THE TEST MODE FOR THE PERFORMANCE OF THIS TEST REACTOR POWER LEVEL
WAS MAINTAINED CONSTANT UNTIL COMPLETION OF THE TEST. THE TESTING WAS
COMPLETED AT 2000 HOURS ON 12-22-80.

S S ZULLA PRESIDENT MANAGER POWER AUTHORITY OF THE STATE OF NEW
YORK
INAIDAN POINT 3 NUCLEAR POWER PLANT PO BOX 215 BUCHANAN NY 10511
PO BOX 215
BUCHANAN NY 10511

12:34 EST

MGMCOMP

8101270 854

5201 (01/78)