

April 21, 1987
87-JK-030N

The following report is submitted as required under Part II, General Conditions, for SPDES permit NY0004472, reporting of non-compliance.

<u>Outfall</u>	<u>Parameter</u>	<u>Reported Maximum Value</u>	<u>Effluent Limit</u>
1) 001A	Flow	33,900 gpd	20,000 gpd

The additional flow (over 20,000 gpd) is due to an increased site population, relative to that upon which treatment plant design was based. Discussions of site population and its effect on treatment plant performance have previously been submitted to your office. Plans to resolve the site's daily flow requirements, are being actively pursued.

JK/pm

8710260102 871019
PDR ADCK 05000286
R PDR



Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, New York 10511-1099

May 27, 1987

Water Division
New York State Department of
Environmental Conservation
50 Wolf Road
Albany, New York 12233

Re: Monthly Discharge Monitoring Report
Permit Number 0004472
Con Edison Indian Point Units 1 and 2
New York Power Authority Unit 3

Gentlemen:

Enclosed are the Discharge Monitoring Reports (DMR's) for the month of April, 1987.

Explanation for permit circulating flow deviations are forwarded to the Department of Environmental Conservation as they occur and, therefore, are not enclosed. The site excursions are listed on Attachments to the cover letter.

Please call either Mr. Joseph J. Higgins of Con Edison at (914) 526-5168, if you have any questions regarding this submission or Mr. James Gillen at (914) 736-8450 of New York Power Authority.

Very truly yours,

John A. Basile, General Manager
Nuclear Power Generation
Con Edison, Indian Point 1 and 2

JJH:sh

Enclosure