

June 22, 1987  
87-JK-037N

The following report is submitted as required under Part II, General Conditions, for SPDES permit NY0004472, reporting of non-compliance.

<u>Outfall</u>	<u>Parameter</u>	<u>Reported Maximum Value</u>	<u>Effluent Limit</u>
1) 001A	Flow	28,900 gpd	20,000 gpd

The additional flow (over 20,000 gpd) is due to an increased site population, relative to that upon which treatment plant design was based. Discussions of site population and its effect on treatment plant performance have previously been submitted to your office. Plans to resolve the site's daily flow requirements, are being actively pursued.

JK/pm

8710260103 871019  
PDR ADOCK 05000286  
R PDR



Consolidated Edison Company of New York, Inc.  
Indian Point Station  
Broadway & Bleakley Avenue  
Buchanan, New York 10511-1099

June 24, 1987

Water Division  
New York State Department of  
Environmental Conservation  
50 Wolf Road  
Albany, New York 12233

Re: Monthly Discharge Monitoring Report  
Permit Number NY 0004472  
Con Edison Indian Point Station Units 1 and 2  
New York Power Authority Unit 3

Gentlemen:

Enclosed are the Discharge Monitoring Reports (DMR's) for the month of May 1987.

Explanations for permit circulating flow deviations are forwarded to the Department of Environmental Conservation as they occur and, therefore, are not enclosed. The site excursions are listed on Attachments to the cover letter.

If you have any questions regarding this submission, please contact Mr. Gerald Rumold of Con Edison at (914) 526-5681 or Mr. James Gillen of New York Power Authority at (914) 736-8450.

Very truly yours,

  
John A. Basile, General Manager  
Nuclear Power Generation  
Con Edison, Indian Point 1 and 2

GR:sh

Enclosure