

August 14, 1987  
JK-87-046N

The following report is submitted to correct previous reports of non-compliance for the months of March, April, May and June 1987. These previous reports, did not list specific dates as required by Part II, General Conditions.

| <u>Outfall</u> | <u>Parameter</u> | <u>Date</u> | <u>Reported Value</u> | <u>Effluent Limit</u> |
|----------------|------------------|-------------|-----------------------|-----------------------|
| 001A           | Flow             | March 2     | 20,700 gpd            | 20,000 gpd            |
|                |                  | March 5     | 28,000 gpd            | 20,000 gpd            |
|                |                  | March 9     | 23,800 gpd            | 20,000 gpd            |
|                |                  | March 18    | 20,700 gpd            | 20,000 gpd            |
|                |                  | March 31    | 31,500 gpd            | 20,000 gpd            |
| -----          |                  |             |                       |                       |
| 001A           | Flow             | April 1     | 33,900 gpd            | 20,000 gpd            |
|                |                  | April 3     | 26,200 gpd            | 20,000 gpd            |
|                |                  | April 8     | 20,400 gpd            | 20,000 gpd            |
|                |                  | April 14    | 27,500 gpd            | 20,000 gpd            |
|                |                  | April 20    | 21,800 gpd            | 20,000 gpd            |
|                |                  | April 23    | 21,600 gpd            | 20,000 gpd            |
| -----          |                  |             |                       |                       |
| 001A           | Flow             | May 5       | 24,400 gpd            | 20,000 gpd            |
|                |                  | May 7       | 23,200 gpd            | 20,000 gpd            |
|                |                  | May 8       | 21,000 gpd            | 20,000 gpd            |
|                |                  | May 11      | 20,100 gpd            | 20,000 gpd            |
|                |                  | May 12      | 22,200 gpd            | 20,000 gpd            |
|                |                  | May 13      | 23,200 gpd            | 20,000 gpd            |
|                |                  | May 14      | 21,400 gpd            | 20,000 gpd            |
|                |                  | May 15      | 24,200 gpd            | 20,000 gpd            |
|                |                  | May 19      | 24,600 gpd            | 20,000 gpd            |
|                |                  | May 20      | 26,000 gpd            | 20,000 gpd            |
|                |                  | May 22      | 28,900 gpd            | 20,000 gpd            |
|                |                  | May 27      | 23,400 gpd            | 20,000 gpd            |
|                |                  | May 28      | 23,000 gpd            | 20,000 gpd            |
| May 29         | 23,000 gpd       | 20,000 gpd  |                       |                       |

8804110199 880405  
PDR ADDCK 05000286  
R DCD

August 14, 1987  
JK-87-046N

| <u>Outfall</u> | <u>Parameter</u> | <u>Date</u> | <u>Reported Value</u> | <u>Effluent Limit</u> |
|----------------|------------------|-------------|-----------------------|-----------------------|
| 001A           | Flow             | June 3      | 33,250 gpd            | 20,000 gpd            |
|                |                  | June 4      | 23,570 gpd            | 20,000 gpd            |
|                |                  | June 5      | 28,750 gpd            | 20,000 gpd            |
|                |                  | June 9      | 25,700 gpd            | 20,000 gpd            |
|                |                  | June 10     | 30,120 gpd            | 20,000 gpd            |
|                |                  | June 11     | 26,650 gpd            | 20,000 gpd            |
|                |                  | June 12     | 28,750 gpd            | 20,000 gpd            |
|                |                  | June 16     | 24,200 gpd            | 20,000 gpd            |
|                |                  | June 17     | 22,200 gpd            | 20,000 gpd            |
|                |                  | June 19     | 30,400 gpd            | 20,000 gpd            |
|                |                  | June 22     | 33,800 gpd            | 20,000 gpd            |
|                |                  | June 23     | 24,000 gpd            | 20,000 gpd            |
|                |                  | June 24     | 30,000 gpd            | 20,000 gpd            |
|                |                  | June 25     | 28,400 gpd            | 20,000 gpd            |
|                |                  | June 26     | 24,400 gpd            | 20,000 gpd            |
|                |                  | June 29     | 28,400 gpd            | 20,000 gpd            |
|                |                  | June 30     | 26,500 gpd            | 20,000 gpd            |