PMSTPCOL PEmails

From: Govan, Tekia
Sent: Tuesday, December 15, 2009 11:20 AM
To: 'Price, John E'
Cc: STPCOL
Subject: Draft RAI 4.6
Attachments: RAI 3975.doc

John,

Please review the attached RAI. If you feel we need a conference call to clarify the requested information, please contact me within 5 business days. If a conference call is not needed (please send an email) I will continue the formal process of issuing the RAI to STPNOC.

This RAI relates to section 4.6 and is a product of the Phase 2 review.

Tekia V. Govan, Project Manager
U.S. Nuclear Regulatory Commission
Office of New Reactors
MS T-6-D48
Washington DC 20555-0001
301-415-6197
Tekia.Govan@nrc.gov

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1954

Mail Envelope Properties (F5A4366DF596BF458646C9D433EA37D71E8467E7C3)

Subject: Draft RAI 4.6
Sent Date: 12/15/2009 11:19:49 AM
Received Date: 12/15/2009 11:19:49 AM
From: Govan, Tekia

Created By: Tekia.Govan@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"'Price, John E'" <jeprice@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	604	12/15/2009 11:19:49 AM
RAI 3975.doc	30202	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 3975 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 04.06 - Functional Design of Control Rod Drive System
Application Section: 4.6

QUESTIONS for Reactor System, Nuclear Performance and Code Review (SRSB)

04.06-***

RAI 3975

This is a follow-up RAI to RAI 2370. In order to complete the review of the applicant's response to RAI 2370, provide the topical report GENE-637-019-0893, "Analysis Guidelines for Backfill Modification of RPV Water Level Instrumentation," Rev. 0.