

  
**MITSUBISHI HEAVY INDUSTRIES, LTD.**  
16-5, KONAN 2-CHOME, MINATO-KU  
TOKYO, JAPAN

December 11, 2009

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attention: Mr. Jeffrey A. Ciocco

Docket No. 52-021  
MHI Ref: UAP-HF-09556

**Subject: MHI's Response to US-APWR DCD RAI No. 492-3898 Rev. 1**

**Reference:** 1) "Request for Additional Information No. 492-3898 Revision 1, SRP Section: 15.00.03 – 15.00.03 - Design Basis Accidents Radiological Consequence Analyses for Advanced Light Water Reactors, Application Section: 15.0.3" dated 11/23/2009.

With this letter, Mitsubishi Heavy Industries, Ltd. ("MHI") transmits to the U.S. Nuclear Regulatory Commission ("NRC") documents entitled "Response to Request for Additional Information No. 492-3898 Rev. 1".

Enclosed 1 provides the response to the 1 question that is contained within Reference 1.

Please contact Dr. C. Keith Paulson, Senior Technical Manager, Mitsubishi Nuclear Energy Systems, Inc. if the NRC has questions concerning any aspect of the submittals. His contact information is below.

Sincerely,

*Y. Ogata*

Yoshiki Ogata,  
General Manager- APWR Promoting Department  
Mitsubishi Heavy Industries, LTD.

Enclosure:

1. Response to Request for Additional Information No. 492-3898 Revision 1

CC: J. A. Ciocco  
C. K. Paulson

Contact Information

C. Keith Paulson, Senior Technical Manager  
Mitsubishi Nuclear Energy Systems, Inc.  
300 Oxford Drive, Suite 301  
Monroeville, PA 15146  
E-mail: ck\_paulson@mnes-us.com  
Telephone: (412) 373-6466

*DOST  
NRC*

Docket No. 52-021  
MHI Ref: UAP-HF-09556

Enclosure 1

UAP-HF-09556  
Docket No. 52-021

Response to Request for Additional Information No. 492-3898  
Revision 1

December 2009

---

---

**RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**

---

---

12/11/2009

**US-APWR Design Certification  
Mitsubishi Heavy Industries  
Docket No.52-021**

**RAI NO.:** NO. 492-3898 REVISION 1  
**SRP SECTION:** 15.00.03 – Design Basis Accidents Radiological  
Consequence Analyses for Advanced Light Water  
Reactors  
**APPLICATION SECTION:** 15.0.3  
**DATE OF RAI ISSUE:** 11/23/2009

---

**QUESTION NO. : 15.00.03-32**

**Background**

In the response to Question 15.00.03-29 (Ref. 1), the applicant stated that the volume of water assumed in calculating the post-accident pH to determine the minimum required amount of NaTB buffer is 879,690 gallons (3,330 m<sup>3</sup>). However, in DCD Table 6.2.5-1, the maximum RWSP volume is given as 651,000 gallons. Further, the response to RAI 15.00.03-27 indicated that 134,730 gallons of RCS water was assumed to be discharged to the sump. The sum of 651,000 gallons plus 134,730 gallons equals 785,730 gallons, which is considerably less than the figure of 879,690 gallons.

**Requested Information**

Please explain the basis for the use of 879,690 gallons for calculating the minimum amount of buffer. The basis should detail the contributions from the various volumes such as the RWSP, RCS, accumulators, any other significant contributions, and any margin added for conservatism.

**References**

1. Letter from Yoshiki Ogata to NRC dated July 13, 2009, Docket No. 52-021, MHI Ref: UAP-HF-09373 Subject: MHI's Response to US-APWR DCD RAI No. 390-3088 Rev. 0 (ADAMS Accession No. ML091602680)

---

**ANSWER:**

The basis for 3,330 m<sup>3</sup>(879,690 gallons), which is used to calculate the minimum buffering agent volume, is shown in Table 1. Margin is not considered except the round-up.

Table 1 Basis for calculating the minimum amount of the buffering agent

Water source	Volume (m <sup>3</sup> )	Basis
RWSP	2,520	Maximum RWSP inventory at normal operation (See Figure 1).  (1) 0 ~ 100% volume: 81,307.6 ft <sup>3</sup> (2) Volume below 0% (excluding sump pit): 5,678.3 ft <sup>3</sup> (3) Sum of four sump pits volume: 1,045.7 ft <sup>3</sup>  (1)+(2)+(3) = 88,031.6 ft <sup>3</sup> ≈ 89,000 ft <sup>3</sup> (2,520 m <sup>3</sup> )
Accumulators	300	Total accumulator water volume = [tank total volume - tank minimum gas space volume] x [Number of Accumulator] = (90m <sup>3</sup> - 15.3m <sup>3</sup> ) x 4 = 298.8 m <sup>3</sup> ≈ 300 m <sup>3</sup>
RCS	510	RCS volume including pressurizer full volume : 502.6 m <sup>3</sup> ≈ 510 m <sup>3</sup>
Total	3,330	2,520 + 300 + 510 = 3,330




Figure 1 Areas for calculating water volume in RWSP

**Impact on DCD**

There is no impact on the DCD.

**Impact on COLA**

There is no impact on the COLA.

**Impact on PRA**

There is no impact on the PRA.