

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
CONSOLIDATED EDISON COMPANY ) Docket No. 50-247  
OF NEW YORK, INC. )  
(Indian Point Station, )  
Unit No. 2) )

APPLICATION FOR AMENDMENT TO  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Consolidated Edison Company of New York, Inc. ("Con Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for an amendment to the Indian Point Unit No. 2 Technical Specifications contained in Appendix A to that license.

Specifically, Con Edison requests changes to sections 3.3, 3.8 and 4.1 of the Technical Specifications to permit a reduction in the minimum water volume requirement for the Refueling Water Storage Tank (RWST) and to establish setpoint requirements for the RWST level alarms. This Application supersedes the Application sworn to on June 10, 1975 by Mr. William J. Cahill, Jr.

The proposed Technical Specification changes consist of the specific revisions set forth in Attachment A to this Application. A safety evaluation of the proposed changes is set forth in Attachment B to this Application. This evaluation demonstrates that the proposed changes do not represent a significant hazards consideration and will not cause any change

8110310050 770406  
PDR ADOCK 05000247  
P PDR

in the types or increase in the amounts of effluents or  
any change in the authorized power level of the facility.

CONSOLIDATED EDISON COMPANY  
OF NEW YORK, INC.

BY *William J. Cahill, Jr.*  
William J. Cahill, Jr.  
Vice President

Subscribed and sworn to before  
me this 28<sup>th</sup> day of March, 1977.

*Angela Roberti*  
Notary Public

ANGELA ROBERTI  
Notary Public, State of New York  
No. 41-8593813  
Qualified in Queens County  
Commission Expires March 30, 1978