

SEP 26 1972

Docket No. 50-247

Consolidated Edison Company
of New York, Inc.
ATTN: Mr. William J. Cahill, Jr.
Vice President
4 Irving Place
New York, New York 10003

Gentlemen:

A failure of an expansion bellows in the circulating water line which serves the main condenser recently occurred at Quad-Cities, Unit 1. The resultant flooding caused degradation of some safety-related equipment.

You are requested to review Indian Point Nuclear Generating Plant, Unit No. 2 to determine whether the failure of any non-Category I (seismic) equipment, particularly in the circulating water system and fire protection system, could result in a condition, such as flooding or the release of chemicals, that might potentially adversely affect the performance of safety-related equipment required for safe shutdown of the facility or to limit the consequences of an accident.

The integrity of barriers to protect critical equipment from potentially damaging conditions should be assumed only when the barrier has been specifically designed for such conditions. If your review determines that safety-related equipment could be adversely affected, provide your plans and schedules for corrective action.

Please submit your response within 30 days of receipt of this letter.

Sincerely,

Original Signed By
R. C. DeYoung

R. C. DeYoung, Assistant Director
for Pressurized Water Reactors
Directorate of Licensing

cc: See next page

Mud [Signature]

8110240339 790926
PDR ADDCK 05000247
P PDR

SURNAME ►

DATE ►

Consolidated Edison Company
of New York, Inc.

- 2 -

cc: Arvin E. Upton, Esquire
LeBoeuf, Lamb, Leiby & MacRae
1821 Jefferson Street, N.W.
Washington, D.C.

DISTRIBUTION:

AEC PDR & Local PDR
Docket File
RP Reading
PWR-2 Reading
SHanauer
RSBoyd
RCDeYoung
DSkovholt
FSchroeder
RRMaccary
DKnuth
RTedesco
HDenton
PWR Branch Chiefs
RO:3
KKniel
MService
OGC
MMcCoy

CRESS:dp OFFICE T6002, R30 9/22/72 DATE	PWR-2 MM MMcCoy:dp 9/25/72	PWR-2 KKniel 9/26/72	OGC 9/25/72 M. KARMAN J.F.S. 9/25/72 9/17/72	Ad/PWRs RCDeYoung 9/26/72		
---	-------------------------------------	----------------------------	--	---------------------------------	--	--