

William J. Cahill, Jr.
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, N Y 10003
Telephone (212) 460-3819

September 21, 1973

Re Indian Point Unit No. 2
AEC Docket No. 50-247

Mr. Eldon J. Brunner, Chief
Facility Test and Startup Branch
U. S. Atomic Energy Commission
631 Park Avenue
King of Prussia, Penn. 19406

Dear Mr. Brunner

This statement is submitted in response to the enclosure transmitted by your letter of August 31, 1973 to Mr. W. E. Caldwell, Jr.

Item No. 1

Maintenance Procedure IA-IAC-18.1, which relates to Instrument Air Compressor corrective maintenance, has been revised to incorporate the degree of detail set forth by your inspector in R.O. Inspection Report 50-247/73-14, Page 8. This revised procedure is now being reviewed and will be issued for use shortly.

Furthermore, Unit No. 2 corrective maintenance procedures have been reviewed relative to the criteria delineated by your inspector, and are being revised where necessary.

Item No. 2

The Nuclear Power Generation Department Manager has issued instructions which require that written approval be obtained for all corrective maintenance procedures. Oral approval of a procedure, except in an emergency, will be invalid and unacceptable. Furthermore, the instructions require that no maintenance work on safety-related equipment will be performed without an approved procedure available.

The corrective maintenance work done on the Instrument Air Compressors and the Pressurizer Safety Valve was conducted in accordance with written procedures which had been orally approved prior to their implementation. As stated above, this work in the future will be done only with a formally approved procedure.

8111070372 731003
PDR ADOCK 05000247
G PDR

Mr. Eldon J. Brunner
Atomic Energy Commission

-2-

September 21, 1973

Re Indian Point Unit No. 2
AEC Docket No. 50-247

Detailed procedures for corrective maintenance as set forth in Regulatory Guide 1.33 have been written and are expected to be approved by October 31, 1973. A complete set of pre-planned preventive maintenance procedures will be available by March 31, 1974.

Very truly yours



William J. Cahill, Jr.
Vice President

md .