

October 10, 1973

Docket No. 50-247

Consolidated Edison Company of New York, Inc.  
ATTN: Mr. William J. Cahill, Jr.  
Vice President  
4 Irving Place  
New York, New York 10003

Gentlemen:

The Regulatory staff has had the subject of anticipated transients without scram (ATWS) in water-cooled reactor power plants under study for some time.

The staff has completed its review of ATWS and has concluded that measures should be taken to improve nuclear plant designs in this regard. Details of the staff review and conclusions and of the steps that should be taken to deal with ATWS are given in the staff "Technical Report on Anticipated Transients Without Scram for Water-Cooled Power Reactors," September 1973, a copy of which is enclosed for your information. The improvement measures acceptable to the staff are outlined in the staff position on ATWS, Appendix A, of the enclosed report in descending order of preference; that is, the "A" sections of the staff position describe the ultimate objective. For those facilities for which the imposition of the requirements of the "A" sections is not practical, the staff will accept the alternate approaches of the "B" or "C" sections subject to the limitations specified in the staff position. The rationale and bases for this approach are given in the enclosed report.

Acceptable measures that should be taken for the subject facility(s) are either those in the "A" or the "C" sections of the staff position. If there is reasonable assurance that the provisions of the "A" sections can be met satisfactorily on a reasonable schedule (less than 3 years) for the subject facility(s), you need not analyze the consequences of ATWS. You must, however, provide sufficient analyses and discussion to justify

OFFICE ▶	<i>S</i>	8111120205 731010			
SURNAME ▶		PDR ADOCK 05000247			
DATE ▶	10/21/73	PDR			

Consolidated Edison Co.  
of New York, Inc.

-2-

October 10, 1973

your position and a commitment that you will meet the provisions of the "A" sections or revert to the provisions of the "C" sections if required by the staff. You should advise the staff by no later than January 1, 1974, of the approach you intend to take and submit a detailed report addressing fully, either the "A" or "C" sections of the staff position by October 1, 1974, as an amendment to the Safety Analysis Report.

The staff is prepared to discuss this matter with you at a mutually agreeable time.

Sincerely,

A. Giambusso, Deputy Director  
for Reactor Projects  
Directorate of Licensing

Enclosure:  
Technical Report on ATWS  
for Water-Cooled Power  
Reactors, September 1973

cc:

Leonard M. Trosten, Esquire  
LeBouef, Lamb, Leiby & MacRae  
1757 N Street, NW  
Washington, D. C. 20036

J. Bruce McDonald, Esquire  
New York State Atomic Energy Council  
99 Washington Avenue  
Albany, New York 12210

Angus Macbeth, Esquire  
Natural Resources Defense Council, Inc.  
15 West 44th Street  
New York, New York 10036

Anthony Z. Roisman, Esquire  
Berlin, Roisman & Kessler  
171 1/2 N Street, NW  
Washington, D. C. 20036

Paul S. Shemin, Esquire  
New York State Attorney General's Office  
80 Centre Street  
New York, New York 10013

OFFICE ▶						
SURNAME ▶						
DATE ▶						

DISTRIBUTION:

AEC PDR  
Local PDR  
Docket file  
PWR-2 Reading  
R. C. DeYoung  
J. Hendrie  
A. Kenneke  
R. W. Klecker  
OGC  
RO (3)  
M. Service  
D. Eisenhut  
Project Manager  
Karl Kniel  
R. R. Maccary  
V. Stello  
R. L. Tedesco  
H. R. Denton  
ACRS (16)  
R. S. Boyd  
A. Giambusso  
RP Reading  
Karl Kniel  
M. Carmon