

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | N | Y | I | P | S | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
R 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

ONIT
8 REPORT SOURCE L 6 | 0 | 5 | 0 | 0 | 0 | 2 | 4 | 7 | 7 | 1 | 0 | 1 | 8 | 7 | 8 | 8 | 1 | 1 | 1 | 7 | 7 | 8 | 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
2 | During the performance of Surveillance Test, PTM-11, Steam Line Pressure
3 | Analog Test, the setting of bistable PC-439A was found to be below the
4 | Tech. Spec. limit of 600 psig. This bistable is used in the logic asso-
5 | ciated with steam break protection circuitry. All other bistables in
6 | this circuitry were found to be within limits. This event is reportable
7 | under the provisions of Tech. Spec. 3.5.1 and Table 3-1 of the Spec.
8 | Similar events: AO-3-2-11, AO-4-2-1, AO-4-2-22. 80

9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
I B 11 | E 12 | E 13 | I N S T R U 14 | C 15 | Z 16
9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
7 8 | 0 3 0 | / | 0 3 | L | 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPR-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
E 18 | Z 19 | Z 20 | Z 21 | 0 0 0 0 | N 23 | Y 24 | N 25 | F 1 8 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | A Foxboro bistable, Model 63S-BR-OCHA (Special) was found to be set 14
11 | psi below the minimum setting of Tech. Spec. Table 3-1. This condition
12 | was attributed to instrument drift. The bistable was reset to the cor-
13 | rect value and returned to service.
14 | _____ 80

5 | FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32)
E 28 | 1 0 0 29 | NA | B 31 | Surveillance Testing
8 9 10 12 13 44 45 46 80

6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36)
Z 33 | Z 34 | NA | NA
8 9 10 11 44 45 80

7 | PERSONNEL EXPOSURES | DESCRIPTION (39)
0 0 0 37 | Z 38 | NA
8 9 11 12 13 80

8 | PERSONNEL INJURIES | DESCRIPTION (41)
0 0 0 40 | NA
8 9 11 12 80

9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION (43)
Z 42 | NA
8 9 10 80

10 | PUBLICITY ISSUED | DESCRIPTION (45)
N 44 | NA
8 9 80

NAME OF PREPARER: John M. Makepeace
PHONE: 914-739-8823
7811280263
NRC USE ONLY
68 69 80
GPO 91-7-726