

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N Y I P S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T

01 REPORT SOURCE L 6 0 5 0 0 0 2 4 7 7 0 5 0 2 7 8 8 0 5 2 6 7 8 9
7 8 60 61 63 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During the performance of surveillance testing of the safety injection
03 system while at cold shutdown for refueling, all components functioned
04 as required with the following exceptions: No. 22 Aux. Component Cool-
05 ing pump did not start as required, and service water valve FCV-1276A
06 did not fully open as required. Redundant equipment for both func-
07 tioned as required. This event is reportable under the provisions of
08 Tech. Spec. 3.3.E.2(b) and 3.3.F.2, respectively.
7 8 9 80

09 SYSTEM CAUSE CAUSE COMPONENT COMP. VALVE
CODE CODE SUBCODE CODE SUBCODE SUBCODE
S B 11 E 12 X 13 X X X X X X 14 Z 15 Z 16
9 10 11 12 13 18 19 20
17 LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
REPORT NUMBER 7 8 0 1 3 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32
ACTION FUTURE EFFECT SHUTDOWN HOURS ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD NO. SUBMITTED FORM SUB. SUPPLIER MANUFACTURER
X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 X 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of this event could not be determined. In both cases, the
11 applicable relays were reset and functioned properly on the introduc-
12 tion of a local safety injection signal. No. 22 Aux. Comp. Cooling
13 Pump - Ingersoll Rand Type 1 1/2 VK centrifugal, vertical pump. FCV-
14 1276A - Associated Control Equipment, 6-inch solenoid operated valve.
7 8 9 80

15 FACILITY % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
STATUS 0 0 0 NA B 31 Surveillance Testing
7 8 9 10 12 13 44 45 46 80
16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80
17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
0 0 0 37 Z 38 NA
7 8 9 11 12 13 80
18 PERSONNEL INJURIES NUMBER DESCRIPTION
0 0 0 40 NA
7 8 9 11 12 80
19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
Z 42 NA
7 8 9 10 80
20 PUBLICATION ISSUED DESCRIPTION
N 44 NA
7 8 9 10 80
8110310671 780526
PDR ADDCK 05000247
S PDR
NRC USE ONLY
7 8 9 10 80
NAME OF PREPARER John M. Makepeace PHONE: 914-739-8823