NRC FORM 366
(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y I P S 2 ② | 0 0 - 0 0 0 0 0 - 0 0 ③ | 4 1 1 1 1 ④ | ⑤
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE L ⑥ | 0 5 0 0 0 2 4 7 ⑦ | 0 2 1 6 7 8 ⑧ | 0 3 1 5 7 8 ⑨
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

02 During the performance of surveillance test PC-R11, refueling water
03 storage tank level transmitter calibration, one of the two low level
04 alarms was found to be set below the minimum level required by Techni-
05 cal Specification 3.3.A.1.k. The redundant low level alarm was found to
06 be within the required range. Therefore, the appropriate alarm signal
07 would have been generated if required.
08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	I B ⑪	E ⑫	E ⑬	I N S T R U ⑭	C ⑮	Z ⑯

⑰ LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
7 8	—	0 0 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS ㉒	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E ⑱	Z ⑲	Z ⑳	Z ㉑	0 0 0 0	N ㉓	N ㉔	N ㉕	B 0 8 0 ㉖

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗

10 This event was caused by alarm setpoint drift of level instrument con-
11 troller LIC-921 (Barton Instrument Company, Model 288). The level
12 controller was reset, thereby returning the RWST level alarm to within
13 limits. This event is reportable under the provisions of Technical
14 Specification 6.9.1.7.2(a).

	FACILITY STATUS	% POWER	OTHER STATUS ㉚	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION ㉜
15	H ㉘	0 0 0 ㉙	NA	B ㉛	Surveillance Testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY ㉟	LOCATION OF RELEASE ㊱
16	Z ㉝	Z ㉞	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION ㊴
17	0 0 0 ㊲	Z ㊳	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION ㊶
18	0 0 0 ㊵	NA

LOSS OF OR DAMAGE TO FACILITY ㊸

	TYPE	DESCRIPTION
19	Z ㊷	NA

PUBLICITY

	ISSUED	DESCRIPTION ㊺
20	N ㊹	NA

8110310715 780315
PDR ADOCK 05000247
S PDR

NRC USE ONLY

NAME OF PREPARER John M. Makepeace PHONE: 914-739-8823

GPO 917-926