

CONTROL BLOCK:

(PLEASE PRINT OR TYPE A REQUIRED INFORMATION)

1 N Y T P S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

1 REPORT SOURCE L 6 0 5 0 0 0 2 4 7 7 0 1 0 4 7 8 8 0 2 2 3 7 8 9
8 9 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 FOR INFORMATION ONLY. During normal operation, service water pump No.
3 21 would not start on demand. The pump was, at the time, aligned to
4 the non-essential header. Local observation indicated arcs being
5 emitted at the pump circuit breaker. The breaker was then racked out
6 and the pump was removed from service.
7
8

9 SYSTEM CODE WA 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE CKTB RK 14 COMP. SUBCODE A 15 VALVE SUBCODE Z 16
8 9 10 11 12 13 14 15 16

17 LER/RO REPORT NUMBER 7 8 21 22 EVENT YEAR SEQUENTIAL REPORT NO. 0 0 1 24 26 OCCURRENCE CODE 9 9 28 29 REPORT TYPE X 30 REVISION NO. 0 32

ACTION TAKEN A 18 Z 19 Z 20 Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 Service water pump No. 21 became inoperable as a result of a failure of
1 its circuit breaker. The breaker, a Westinghouse Type DB-50, was re-
2 paired by renewing a dashpot time delay element, style 502B402001.
3 The pump was then declared operable and was returned to service.
4

5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 47 DESCRIPTION NA 43
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8110310834 780223
PDR ADOCK 05000247
S PDR

NRC USE ONLY