

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

December 12, 1975

Consolidated Edison Company of  
New York, Inc.  
Attention: Mr. W. J. Cahill, Jr.  
Vice President  
4 Irving Place  
New York, NY 10003


Docket No. 50-247  
50-03

Gentlemen:

Enclosed is IE Bulletin No. 75-08 which requires action by you with regard to your pressurized water reactor facility(ies) with an operating license(s).

Should you have questions regarding this bulletin or the actions required of you, please contact this office.

Sincerely,

  
James P. O'Reilly  
Director

Enclosure:  
IE Bulletin No. 75-08

Approved by GAO, B-180225 (R0072), clearance expires 7/31/77. Approval was given under a blanket clearance specifically for identified generic problems.

cc: W. Stein, Manager, Nuclear Power Generation Department  
S. Salay, Station Manager  
A. E. Upton, Esquire  
J. M. Makepeace, Technical Operations Director  
A. Z. Roisman, Counsel for Citizens Committee for  
Protection of the Environment

bcc: IE Files  
PDR  
Local PDR

ELD  
REG:I Reading Room  
State of New York  
Reactor Facilities Branch

8111070275 751212  
PDR ADOCK 05000003  
Q PDR

Inspection and Enforcement  
Bulletin No. 75-08  
December 12, 1975

**PWR PRESSURE INSTRUMENTATION**

**DESCRIPTION OF CIRCUMSTANCES:**

During a recent review of plant heatup and cooldown records at an operating nuclear power plant, it was determined that continuously recorded data was not available to verify adherence to the temperature/pressure limitations specified in the technical specifications. Such information is necessary for determining trends and for evaluating pressure transients, as shown during the reviews of recent rapid pressure increases of the reactor coolant system (RCS) at several plants and the overpressurization of the RCS at another.

**ACTION REQUESTED OF LICENSEES:**

PLEASE PROVIDE THE FOLLOWING INFORMATION IN WRITING TO THIS OFFICE WITHIN 30 DAYS AFTER RECEIPT OF THIS Bulletin:

1. Provide a description of reactor coolant system temperature and pressure instrumentation which allows you to verify adherence to the temperature/pressure limitations in your technical specifications.
2. If you do not have the capability to continuously record reactor coolant system temperature and pressure during heatup and cooldown as well as during power operation, describe what action you have taken or plan to take to provide assurance that the temperature/pressure limitations in your technical specifications are met.

dupe of  
~~7904200116~~