

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME	LICENSE NUMBER	LICENSE TYPE	EVENT TYPE
<span style="border: 1px solid black; padding: 2px;">01</span> N Y I P S 2	0 0 - 0 0 0 0 0 - 0 0 0 4 1	1 1	0 3
7 8 9 14	15 25 26 30		31 32

CATEGORY	REPORT TYPE	REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
<span style="border: 1px solid black; padding: 2px;">01</span> CONT	<span style="border: 1px solid black; padding: 2px;">L</span>	<span style="border: 1px solid black; padding: 2px;">L</span>	0 5 0 - 0 2 - 4 7	0 3 1 5 7 6	0 4 0 9 7 6
7 8 57 58	59 60		61 68	69 74	75 80

**EVENT DESCRIPTION**

02 During normal operation, process radiation monitor R-12 and associated  
03 monitor R-11, became inoperable due to a seized sample pump. The humid-  
04 ity and condensate flow systems, as well as the instrumentation required  
05 for a water inventory balance, were operable. The pump was restored to  
06 service within the required Tech Spec time limit. Similar events (Cont'd)

SYSTEM CODE	CAUSE CODE	COMPONENT CODE	PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER	VIOLATION
<span style="border: 1px solid black; padding: 2px;">07</span> M C	<span style="border: 1px solid black; padding: 2px;">E</span>	P U M P X X	<span style="border: 1px solid black; padding: 2px;">N</span>	X 9 9 9	<span style="border: 1px solid black; padding: 2px;">N</span>
7 8 9 10	11	12 17	43	44 47	48

**CAUSE DESCRIPTION**

08 A Conde Dry Air Pump, Model 6SFCW, for process radiation monitors R-12  
09 and R-11 was found to have seized.  
10

FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
<span style="border: 1px solid black; padding: 2px;">11</span> E	1 0 0	NA	<span style="border: 1px solid black; padding: 2px;">A</span>	NA
7 8 9	10 12 13		44 45	46 80

  

FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
<span style="border: 1px solid black; padding: 2px;">12</span> Z	<span style="border: 1px solid black; padding: 2px;">Z</span>	NA	NA
7 8 9	10 11	44	45 80

**PERSONNEL EXPOSURES**

NUMBER	TYPE	DESCRIPTION
<span style="border: 1px solid black; padding: 2px;">13</span> 0 0 0	<span style="border: 1px solid black; padding: 2px;">Z</span>	NA
7 8 9 11	12	13 80

**PERSONNEL INJURIES**

NUMBER	DESCRIPTION
<span style="border: 1px solid black; padding: 2px;">14</span> 0 0 0	NA
7 8 9 11	12 80

**PROBABLE CONSEQUENCES**

15 NA

**LOSS OR DAMAGE TO FACILITY**

TYPE	DESCRIPTION
<span style="border: 1px solid black; padding: 2px;">16</span> Z	NA
7 8 9 10	80

**PUBLICITY**

17 NA

8111090042 760409  
 PDR ADOCK 05000247  
 S PDR

**ADDITIONAL FACTORS**

18 (Event Desc. Cont)-relating to these monitors occurred on Feb.9,1976  
19 and Feb.26, 1976.(R.O.-76-2-10(B)).

NAME: Michael F. Shatkouski

(914)-739-8823

PHONE: \_\_\_\_\_