

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME:

01	N	Y	I	P	S	2
----	---	---	---	---	---	---

 LICENSE NUMBER:

0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---

 LICENSE TYPE:

4	1	1	1	1
---	---	---	---	---

 EVENT TYPE:

0	1
---	---

CATEGORY:

01	CONT
----	------

 REPORT TYPE:

L

 REPORT SOURCE:

L

 DOCKET NUMBER:

0	5	0	0	2	4	7
---	---	---	---	---	---	---

 EVENT DATE:

0	8	1	9	7	5
---	---	---	---	---	---

 REPORT DATE:

0	9	1	8	7	5
---	---	---	---	---	---

EVENT DESCRIPTION

02 During performance of periodic surveillance test PT-Q7 (Electrical Heat
Tracing) it was found that an open existed in a heat tracing circuit for
03 No. 21 Boric Acid Transfer Pump. The redundant heat tracing circuit was
04 placed in service. Redundant Pump No. 22 was operable and available.
05 [A.O. -75-2-17(B)]

SYSTEM CODE:

P	C
---	---

 CAUSE CODE:

E

 COMPONENT CODE:

H	E	A	T	E	R
---	---	---	---	---	---

 PRIME COMPONENT SUPPLIER:

N

 COMPONENT MANUFACTURER:

Z	9	9	9
---	---	---	---

 VIOLATION:

N

CAUSE DESCRIPTION

08 The wire in a heat tracing circuit on the suction of the pump developed
09 an open. The open was caused by a boric acid leak from a flange gasket
10 on the suction of the pump. The gasket was replaced and the wire was
repaired.

FACILITY STATUS:

E

 % POWER:

0	8	9
---	---	---

 OTHER STATUS:

N.A.

 METHOD OF DISCOVERY:

B

 DISCOVERY DESCRIPTION:

Periodic Surveillance Test

FORM OF ACTIVITY RELEASED:

Z

 CONTENT OF RELEASE:

Z

 AMOUNT OF ACTIVITY:

N.A.

 LOCATION OF RELEASE:

N.A.

PERSONNEL EXPOSURES

13 NUMBER:

0	0	0
---	---	---

 TYPE:

Z

 DESCRIPTION:

N.A.

PERSONNEL INJURIES

14 NUMBER:

0	0	0
---	---	---

 DESCRIPTION:

N.A.

PROBABLE CONSEQUENCES

15 N.A.

LOSS OR DAMAGE TO FACILITY

16 TYPE:

Z

 DESCRIPTION:

N.A.

PUBLICITY

17 N.A.

ADDITIONAL FACTORS

18 N.A.

19 N.A.

8111090223 750918
PDR ADOCK 05000247
S PDR

NAME: Michael Shatrowski

PHONE: (914)-739-8823