

William J. Cahill, Jr.
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, N Y 10003
Telephone (212) 460-3819

April 13, 1977
Re: Indian Point Unit Nos. 2&3
Docket Nos. 50-247 and 50-286

Director of Nuclear Reactor
Regulation
ATTN: Mr. Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Dear Sir:

REGULATORY DOCKET FILE COPY

Con Edison's proposed Overpressure Protection Systems for Indian Point Unit Nos. 2 and 3 were submitted to the Commission by letters dated February 28, 1977.

To aid in the evaluations of these proposed systems, your staff has requested information concerning the integrated fast neutron flux at the interior wall of the reactor vessel beltline region. As of March 31, 1977, the integrated neutron flux in this region with energies greater than 1 MEV was approximately 8.51×10^{17} neutrons per square centimeter for Indian Point Unit No. 2 and 3.19×10^{17} neutrons per square centimeter for Indian Point Unit No. 3.

Should you or your staff have any further questions, we would be happy to discuss them with you at your convenience.

Very truly yours,


William J. Cahill, Jr.
Vice President

Copy to: Mr. George T. Berry
General Manager and Chief Engineer
Power Authority of the State of New York
10 Columbus Circle
New York, N. Y. 10019

8111230387 770413
PDR ADDCK 05000247
PDR

771090013