



STATE OF NEW YORK  
 ENERGY OFFICE  
 SWAN STREET BUILDING  
 CORE 1 - 2ND FLOOR  
 EMPIRE STATE PLAZA  
 ALBANY, N.Y. 12223  
 (518) 474-8313

6



January 10, 1977

Mr. Benard C. Rusche, Director  
 Office of Nuclear Reactor Regulation  
 U.S. Nuclear Regulatory Commission  
 Washington, D. C. 20555

Dear Mr. Rusche: Re: Dockets 50-247 and 50-286


After Mr. Pollard announced his resignation from the Nuclear Regulatory Commission (NRC) and stated his allegations of safety shortcomings at the Indian Point plants, my staff initiated an independent evaluation of the allegations. This evaluation included: a review of all the documents available regarding Mr. Pollard's allegations and the components, systems and structures in question; a review of the applicable NRC General Design Criteria and Regulatory Guides; and discussions with representatives of the Consolidated Edison Company of New York, Inc., NRC and the Electric Power Research Institute regarding specific aspects of component and system design and operation.

With two exceptions we have concluded that, prior to Mr. Pollard's resignation, the NRC had adequately evaluated these contentions and that adequate safety margins exist on these plants with respect to the issues raised. The two exceptions relate to the probability of tornado damage to buildings containing safety related equipment in Indian Point Unit 2 and the containment isolation features of the two auxiliary steam lines in Indian Point Units 2 and 3. Comments on these two items follow.

\*\*\*\*\*

Probability of Tornado Damage

Insufficient data were available to determine the adequacy of safety margins if a tornado strikes the site. Since many of the buildings (diesel generator, control room, fuel storage) were not designed specifically to resist a tornado, significant damage could be done to safety related components by a tornado. The NRC evaluation determined that the probability



675

8111230591 770110  
 PDR ADOCK 05000247  
 PDR  
 H

Mr. Benard C. Rusche, Director

- 2 - January 10, 1977

of a design basis tornado was  $2 \times 10^{-8}$  per year. However, no mention was made of the probability of having a less severe tornado which could cause significant damage to safety related components. This latter value is important because, as indicated by the NRC, these buildings may not be able to withstand a tornado which is substantially less severe than the current design basis tornado.

#### Containment Isolation

The two auxiliary steam lines in question (nos. 45 and 46 of figure 5.2-18 of the Indian Point Unit 2 FSAR) are the auxiliary steam supply and condensate return lines inside containment which are utilized during plant shutdowns. Each line has a single isolation valve and does not appear to satisfy any of the other requirements of the General Design Criteria, as these requirements have been interpreted by the NRC in the evaluation of the other containment isolation features of other lines.

\*\*\*\*\*

#### Recommendations

We have concluded that the NRC should:

1. Evaluate, if it has not already done so, the magnitude of tornado which could cause substantial damage to safety related components at Indian Point Unit 2 and the probability that any tornado exceeding this magnitude will occur at this site. These studies should consider tornado induced missile effects as well as direct wind effects; and
2. Re-evaluate the containment isolation features of the Indian Point Unit 2 and 3 auxiliary steam lines to ensure that the isolation requirements are indeed satisfied.

Please advise me of the results of the evaluation of these two items as soon as they become available.

Sincerely,



T. K. DeBoer, Director  
Technological Development Program

TKD:mfh

FROM: **TABelear, Director  
Technological Dev. Program  
State of New York, Energy Office**

DATE OF DOCUMENT

**1/10/77**

DATE RECEIVED

**1/17/77**

NO.:

**NEE-1404**

LTR.

MEMO:

RT:

OTHER:

ORIG:

CC:

OTHER:

TO: **ECRusche**

ACTION NECESSARY

CONCURRENCE

DATE ANSWERED:

NO ACTION NECESSARY

COMMENT

BY: **2/1/77**

CLASSIF.: POST OFFICE

REG. NO.:

FILE CODE:

REFERRED TO

DATE

RECEIVED BY

DATE

DESCRIPTION: (Must Be Unclassified)

**Request for evaluation of two  
items - Probability of  
Hornado Damage and Containment  
Isolation**

**MEineman**

**1/18/77**

**ORIGINAL IMAGING**

**Copy to:**

**TO DOCKET FILE FOR**

**ECCase**

**JMiller**

**EBoyd**

**EDenton**

**VStelle**

**FDR 50-247 and 286**

**PROPER DISTRIBUTION**

ENCLOSURES:

REMARKS:

FROM: <b>E. DeBoer, Director          Technological Dev. Program          State of New York, Energy Office</b>	DATE OF DOCUMENT <b>1/10/77</b>	DATE RECEIVED <b>1/17/77</b>	NO.: <b>NRC-1404</b>
TO: <b>BCRusche</b>	LTR. <input checked="" type="checkbox"/> MEMO: <input type="checkbox"/>	REPORT: <input type="checkbox"/>	OTHER: <input type="checkbox"/>
CLASSIF.: POST OFFICE REG. NO:	ORIG. <input checked="" type="checkbox"/> CC: <input type="checkbox"/>	OTHER: <input type="checkbox"/>	ACTION NECESSARY <input checked="" type="checkbox"/> CONCURRENCE <input type="checkbox"/> NO ACTION NECESSARY <input type="checkbox"/> COMMENT <input type="checkbox"/>
DESCRIPTION: (Must Be Unclassified) <b>Request for evaluation of two          items - Probability of          Rorardo Damage and Containment          Isolation</b>	FILE CODE:	DATE ANSWERED: BY: <b>2/1/77</b>	
ENCLOSURES:	REFERRED TO <b>Reineman</b>	DATE <b>1/18/77</b>	RECEIVED BY <b>ORIGINAL INCOMING</b>
REMARKS:	Copy to:	TO DOCKET FILE FOR	PROPER DISTRIBUTION
	<del>EC Case -</del> <b>JRM/ller</b> <b>Blloyd</b>		
	<b>Henton</b> <b>VStello</b>		
	<b>PDR 50-247 and 286</b>		



STATE OF NEW YORK  
ENERGY OFFICE  
SWAN STREET BUILDING  
CORE 1 - 2ND FLOOR  
EMPIRE STATE PLAZA  
ALBANY, N.Y. 12223  
(518) 474-8313

January 10, 1977

Mr. Benard C. Rusche, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Rusche:

Re: Dockets 50-247 and 50-286

After Mr. Pollard announced his resignation from the Nuclear Regulatory Commission (NRC) and stated his allegations of safety shortcomings at the Indian Point plants, my staff initiated an independent evaluation of the allegations. This evaluation included: a review of all the documents available regarding Mr. Pollard's allegations and the components, systems and structures in question; a review of the applicable NRC General Design Criteria and Regulatory Guides; and discussions with representatives of the Consolidated Edison Company of New York, Inc., NRC and the Electric Power Research Institute regarding specific aspects of component and system design and operation.

With two exceptions we have concluded that, prior to Mr. Pollard's resignation, the NRC had adequately evaluated these contentions and that adequate safety margins exist on these plants with respect to the issues raised. The two exceptions relate to the probability of tornado damage to buildings containing safety related equipment in Indian Point Unit 2 and the containment isolation features of the two auxiliary steam lines in Indian Point Units 2 and 3. Comments on these two items follow.

\*\*\*\*\*

Probability of Tornado Damage

Insufficient data were available to determine the adequacy of safety margins if a tornado strikes the site. Since many of the buildings (diesel generator, control room, fuel storage) were not designed specifically to resist a tornado, significant damage could be caused to safety related components by a tornado. The NRC evaluation determined that the probability

*Sup*

~~8111230591~~

247  
Mis ap 4

of a design basis tornado was  $2 \times 10^{-8}$  per year. However, no mention was made of the probability of having a less severe tornado which could cause significant damage to safety related components. This latter value is important because, as indicated by the NRC, these buildings may not be able to withstand a tornado which is substantially less severe than the current design basis tornado.

#### Containment Isolation

The two auxiliary steam lines in question (nos. 45 and 46 of figure 5.2-18 of the Indian Point Unit 2 FSAR) are the auxiliary steam supply and condensate return lines inside containment which are utilized during plant shutdowns. Each line has a single isolation valve and does not appear to satisfy any of the other requirements of the General Design Criteria, as these requirements have been interpreted by the NRC in the evaluation of the other containment isolation features of other lines.

\*\*\*\*\*

#### Recommendations

We have concluded that the NRC should:

1. Evaluate, if it has not already done so, the magnitude of tornado which could cause substantial damage to safety related components at Indian Point Unit 2 and the probability that any tornado exceeding this magnitude will occur at this site. These studies should consider tornado induced missile effects as well as direct wind effects; and
2. Re-evaluate the containment isolation features of the Indian Point Unit 2 and 3 auxiliary steam lines to ensure that the isolation requirements are indeed satisfied.

Please advise me of the results of the evaluation of these two items as soon as they become available.

Sincerely,



T. K. DeBoer, Director  
Technological Development Program

TKD:mfh