

(0.3) / 1.1 POTENTIAL SETTLEMENT BASED ON 1.5% ℄ CRITERIA (INCHES)
POTENTIAL SETTLEMENT BASED ON 6% ℄ CRITERIA (INCHES)

▽ DESIGN WATER TABLE
▼ WATER TABLE (24 HR)
MH SOIL CLASSIFICATION
13 BLOW COUNT
POTENTIALLY LIQUEFIABLE SOIL (SEE NOTE)
-WS WEATHERED SHALE

NOTE:
1. LIQUEFACTION BASED ON TOP OF GROUND ACCELERATION OF 0.4g AND SEED - IDRISS (1971) CORRELATION FOR SANDS.

Added by Amendment 50

WATTS BAR NUCLEAR PLANT
FINAL SAFETY ANALYSIS REPORT

CATEGORY I ELECTRICAL CONDUITS
SECTION F - F SHEET 1 OF 2
FIGURE 2.5-576