U. S. NUCLEAR REGULATORY COMMISSION NRC FORM 366 (7.77) LICENSEE EVENT REPORT "UPDATE REPORT-PREVIOUS REPORT DATE -APRIL 6, (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) CONTROL BLOCK:](1)(3 200 0 P S 2 0 0 0 0 01 NYI 0 LICENSE LICENSE NUMBER 15 LICENSEE CODE CON'T (9) (8) D O [0]3REPORT 101 4 7 2 3 7 8 50 0 0 2 L (6) 0 1 SOURCE L REPORT DATE 68 69 EVENT DATE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) While shutdown for refueling on March 30, 1978, we were advised by 0 2 Westinghouse that they had identified a generic error in their NRC 03 approved ECCS Evaluation Model. The calculational code did not full 0 4 account for the Zircaloy/water reaction heating effect which, by itself. 0 5 yielded higher calculated maximum peak clad temperatures for 0 6 Westinghouse plants. This event was of the type described in Tech. Sped. 0 7 6.9.1.7.1.(h). 0 8 80 COMP VALVE SUBCODE CAUSE SUBCODE SYSTEM CAUSE COMPONENT CODE SUBCODE CODE CODE Z (15 Z (13) Z Ζ 2 ZZ Z (14) Z (16) Z X (12) (11) 0 9 19 18 13 12 REVISION OCCURRENCE SEQUENTIAL REPORT CODE EVENT YEAR TYPE NO. REPORT NO. LER/RO 0111 0 11 X 1 0 (17)REPORT NUMBER 31 32 26 27 28 29 30 22 NPRD-4 PRIME COMP. COMPONENT ATTACHMENT EFFECT ON PLANT SHUTDOWN METHOD ACTION FUTURE HOURS (22) SUBMITTED FORM SUB. SUPPLIER MANUFACTURER TAKEN ACTION 18 Z 000 Z(21) 0 Y (23) N (24) Z (25 9 9 9 Z (26 (20) (19 36 42 35 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Short-term corrective action required a reduction in maximum peaking 1 0 [factor (F₀) from 2.32 to 2.24. Subsequent reanalysis using an MRC 1 1 roved modified Westinghouse ECCS Evaluation Model (Feb. 1978)demon 1 2 strated that with a maximum Fo of 2.31. PCT the calculated maximum 1 3 2200°F would remain below the 10CFR50. App. of Κ. acceptance erion 1 4 80 9 8 METHOD OF FACILITY OTHER STATUS DISCOVERY DESCRIPTION (32) DISCOVERY % POWER 0 0 0 (29) NA D (31) Vendor Notification H (28) 5 9 ACTIVITY CONTENT 45 80 12 13 8 LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35) RELEASED OF RELEASE Z 33 Z 34 NA 6 NA 80 10 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE 0 0 37 Z 38 NA 0 7 80 PERSONNEL INJURIES DESCRIPTION (41) NUMBER 0 0 0 40 NA 8 80 9 11 12 LOSS OF OR DAMAGE TO FACILITY (43 DESCRIPTION 790122012 10 80 PUBLICITY NRC USE ONLY DESCRIPTION (45) ISSUED N (44) NA 0 68 69 80 10 10 Charles W. Jackson 212-460-4681 PHONE .. NAME OF PREPARER

ATTACHMENT I

Docket No. 50-247

LER-78-010/01X-1

Consolidated Edison Co. of N.Y., Inc.

Indian Point Unit No. 2

On March 23, 1978, Consolidated Edison was advised by Westinghouse Electric Corporation that they had identified a generic error in their NRC approved Emergency Core Cooling System (ECCS) Evaluation Model for compliance with the Final Acceptance Criteria (FAC) of Appendix K to 10 CFR Part 50. Westinghouse had determined that their ECCS calculational code did not fully account for the heating effect of the Zircaloy/water reaction following a postulated loss-of-coolant accident (LOCA). The correction for the code deficiency at the time yielded higher calculated maximum peak clad temperatures (PCT) for all Westinghouse plants. The event was of the type described in Technical Specification 6.9.1.7.1.(h).

At the time of the event, discussions between Westinghouse and the Regulatory Staff resulted in the determination that a reduction in the maximum total nuclear peaking factor (FQ) would adequately offset the generic deficiency on a temporary basis until selected plant specific reanalyses could be performed with a corrected Westinghouse ECCS Evaluation Model. For Indian Point Unit No. 2, it was determined that a reduction in the maximum allowable FQ to 2.24 would assure that the calculated maximum PCT remained below the 10 CFR 50, Appendix K, acceptance criterion of 2200°F. This was documented in an April 17, 1978 letter from Mr. William J. Cahill, Jr. (Consolidated Edison) to Mr. A. Schwencer (NRC). On April 27, 1978, the Commission issued an Order for Modification of License imposing a new maximum FQ of 2.24 and requiring reanalysis using a corrected ECCS evaluation model as soon as possible. The imposition of an FQ of 2.24 had no effect on the full power operation of the unit.

Subsequent to this event, a specific Indian Point Unit No. 2 ECCS large break reanalysis was performed by Westinghouse using the recently approved February 1978 Westinghouse ECCS Evaluation Model. This reanalysis included evaluation of a spectrum of breaks (i.e., Cp=1.0, 0.8, 0.6 and 0.4) and was performed in accordance with the Commission's April 27, 1978 Order for Modification of License. The reanalysis incorporated lower required accumulator water volumes and a reduction in the maximum total nuclear peaking factor ($F_{\rm O}$) from 2.32 to 2.31. The results of the specific reanalysis yielded a new limiting break size, C_D=0.6. For this worst case break, the calculated maximum peak clad temperature (PCT) was 2172.5°F. Thus, the maximum PCT remains below the 10 CFR 50, Appendix K, acceptance criterion of 2200°F.

The specific Indian Point Unit No. 2 ECCS Reanalysis and results were forwarded to the NRC Regulatory Staff by letter dated January 5, 1979 from Mr. William J. Cahill, Jr. to Mr. Harold R. Denton.