NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYIPS2 (2) | 00-00000-00 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000247 (7) | 012779 (8) | 022679 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | With Units No. 2 and No. 3 each operating at 100% reactor power, cal-
03 | culations performed on 1-27-79 utilizing the equation prescribed at that
04 | time by ETSR 2.1.3.1, indicated the heat rejection to the river was in
05 | excess of the 16.3 x 10^9 BTU/Hr. maximum permitted by the ETSR. There
06 | were no adverse effects to the environment as a result of this event. A
07 | change to the ETSR was issued by NRC on 2-15-79 clarifying this require-
08 | ment and deleting the referenced equation (Ref: LER-78-025 & LER-78-034).
7 8 9 80

09 | SYSTEM CODE HF (11) | CAUSE CODE D (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 | — | SEQUENTIAL REPORT NO. 005 | / | OCCURRENCE CODE 04 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN Z (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | This event was attributable to the method prescribed by ETSR at that time
11 | for calculating the heat rejected to the river. An alternate, more
12 | appropriate and more accurate method of calculation using reactor heat
13 | output less net generation showed the heat rejected to the river on the
14 | above date was considerably less than the ETSR maximum allowable.
7 8 9 80

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Testing
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES
17 | NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

PERSONNEL INJURIES
18 | NUMBER 000 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE Z (42) | DESCRIPTION NA
7 8 9 10 80

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 10 68 69 80

7903060217

NAME OF PREPARER John M. Makepeace PHONE: 914-739-8823

GPO 917-926