

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y I P S 2 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 4 7 7 0 3 3 1 7 9 8 0 4 2 7 7 9 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation, electric heat trace circuit 51B was found to

0 3 have an inoperable primary circuit. This circuit heat traces the

0 4 thrust balance line for safety injection pump No. 23. The backup chan-

0 5 nel for heat tracing of the affected line was operable. The primary

0 6 circuit was repaired and returned to service within the time limits of

0 7 Technical Specification 3.3.A.2.e.

0 8 7 8 9 80

0 9 SYSTEM CODE S F 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE H E A T E R 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 7 9 21 22 SEQUENTIAL REPORT NO. 0 1 4 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32

ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 37 40 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 3 3 3 2 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Two Chromalox Strip Heater Elements, Cat. No. PT-512, were found to be

1 1 defective, causing an open circuit in the recirculation line No. 467

1 2 heat tracing. The elements were replaced and the circuit was returned

1 3 to service.

1 4 7 8 9 80

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Routine Surveillance 32

1 6 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

7905040279

NAME OF PREPARER John M. Makepeace

PHONE: 914-739-8823