NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y I P S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 | 9 LICENSEE CODE 14 | 15 LICENSE NUMBER 25 | 26 LICENSE TYPE 30 | 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 4 7 (7) | 0 3 3 1 7 9 (8) | 0 4 2 7 7 9 (9)
7 8 | 60 61 DOCKET NUMBER 68 | 69 EVENT DATE 74 | 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, electric heat trace circuit 51B was found to
03 have an inoperable primary circuit. This circuit heat traces the
04 thrust balance line for safety injection pump No. 23. The backup chan-
05 nel for heat tracing of the affected line was operable. The primary
06 circuit was repaired and returned to service within the time limits of
07 Technical Specification 3.3.A.2.e.
08

09 SYSTEM CODE S F (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE H E A T E R (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 1 4 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER C 3 3 2 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Two Chromalox Strip Heater Elements, Cat. No. PT-512, were found to be
11 defective, causing an open circuit in the recirculation line No. 467
12 heat tracing. The elements were replaced and the circuit was returned
13 to service.
14

15 FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Routine Surveillance

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

7905040279

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER John M. Makepeace PHONE: 914-739-8823

GPO 917-926