NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | LICENSEE CODE: N Y I P S 2 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT (5)

CON'T 0 1 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 2 4 7 (7) | EVENT DATE: 0 6 1 3 7 9 (8) | REPORT DATE: 0 7 1 3 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During end of cycle operation while conducting surveillance test PI-V1
0 3 (B), Shock Suppressor Inspection, it was noted that snubber SR-M24 on
0 4 line MS-3 had less than the required fluid level. The plant was removed
0 5 from service for a scheduled refueling - maintenance outage within the
0 6 time period permitted by Tech. Spec. 3.12.3. (Similar events: AO4-2-3,
0 7 AO4-2-25 and RO 76-2-5).
0 8

0 9 | SYSTEM CODE: C C (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: B (13) | COMPONENT CODE: S U P O R T (14) | COMP. SUBCODE: D (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR: 7 9 | — | SEQUENTIAL REPORT NO.: 0 1 6 | / | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | — | REVISION NO.: 0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	C (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	B 2 0 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause of hydraulic fluid loss from the Bergen-Paterson hydraulic
1 1 snubber, model HSSA-3-6, could not be determined. The snubber will be
1 2 replaced in like and kind.
1 3
1 4

1 5 | FACILITY STATUS: E (28) | % POWER: 0 9 5 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: B (31) | DISCOVERY DESCRIPTION (32): Surveillance Testing

1 6 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES
1 7 | NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES
1 8 | NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)
1 9 | TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY
2 0 | ISSUED: N (44) | DESCRIPTION (45): NA

7907240 397

NRC USE ONLY

NAME OF PREPARER: John M. Makepeace

PHONE: 914-739-8823

GPO 917-926