NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYIPS2 (2) 00-00000-00 (3) 41111 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 REPORT SOURCE L (6) 0500024 7 (7) 081779 (8) 091479 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While shutdown for refueling, a review of the results of surveillance
03 test PI-V1 (A) indicated that the reservoir associated with the snubber
04 bank located at the top of the support structure for No. 24 steam
05 generator had less than the required fluid level - technical spec-
06 ification 3.12.
07
08

09	SYSTEM CODE	CC (11)
	CAUSE CODE	E (12)
	CAUSE SUBCODE	B (13)
	COMPONENT CODE	SUPORT (14)
	COMP. SUBCODE	D (15)
	VALVE SUBCODE	Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 — SEQUENTIAL REPORT NO. 021 / OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	X (19)	Z (20)	Z (21)	0000	N (23)	N (24)	N (25)	G255 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Tubing fitting leakage resulted in fluid loss from the Grinnel 8" bore,
11 5" stroke, snubber oil reservoir. Fittings were tightened and reser-
12 voir refilled to the required level. To provide further assurance
13 that the proper oil level will be maintained increased surveillance of
14 reservoir fluid level will be performed.

15 FACILITY STATUS H (28) % POWER 000 (29) OTHER STATUS (30) NA — METHOD OF DISCOVERY B (31) — DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) — CONTENT OF RELEASE Z (34) — AMOUNT OF ACTIVITY (35) NA — LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES — NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) NA

18 PERSONNEL INJURIES — NUMBER 000 (40) DESCRIPTION (41) NA

7909260419

19 LOSS OF OR DAMAGE TO FACILITY (43) — TYPE Z (42) DESCRIPTION NA

20 PUBLICITY — ISSUED N (44) DESCRIPTION (45) NA — NRC USE ONLY

NAME OF PREPARER J.M. Makepeace — PHONE: 914 739-8823

GPO 917-926