NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

8005200677

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYIPS2 (2) | 00-00000-00 (3) | 41111 (4) | (5)
7 8 | 9 LICENSEE CODE 14 | 15 LICENSE NUMBER 25 | 26 LICENSE TYPE 30 | 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000247 (7) | 040980 (8) | 050980 (9)
7 8 | 60 | 61 DOCKET NUMBER 68 | 69 EVENT DATE 74 | 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal plant operation, it was noted while performing Sur-
03 veillance Test PT-M21 on No. 22 Diesel Generator that the temperature
04 of Diesel Cylinder Nos. 7 and 8 was above normal. The Diesel Generator
05 was removed from service for inspection and correction of the con-
06 dition. This event is reportable under the provisions of Technical
07 Specification 3.7.B.1.
08

09 SYSTEM CODE EE (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE ENGINE (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
7 8 | 9 10 | 11 | 12 | 13 18 | 19 | 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 (21 22) | — (23) | SEQUENTIAL REPORT NO. 002 (24 26) | / (27) | OCCURRENCE CODE 03 (28 29) | REPORT TYPE L (30) | — (31) | REVISION NO. 0 (32)

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 (37 40) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER A115 2 (26)
33 | 34 | 35 | 36 | 41 | 42 | 43 | 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cylinder valve timing for an Alco, Model No. 16-251-E1, Diesel
11 Engine was found to be out of specified limits. After adjusting
12 the valve timing, the Diesel Engine was retested satisfactorily and
13 returned to an operable status.
14

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Testing
7 8 | 9 | 10 12 | 13 44 | 45 | 46 80

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 | 9 | 10 | 11 44 | 45 80

PERSONNEL EXPOSURES
17 NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 | 9 11 | 12 | 13 80

PERSONNEL INJURIES
18 NUMBER 000 (40) | DESCRIPTION (41) NA
7 8 | 9 11 | 12 80

LOSS OF OR DAMAGE TO FACILITY
19 TYPE Z (42) | DESCRIPTION (43) NA
7 8 | 9 | 10 80

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 | 9 | 10 68 | 69 80

NAME OF PREPARER John M. Makepeace PHONE: 914-739-8823