



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
475 ALLENDALE ROAD
KING OF PRUSSIA, PA 19406-1415

December 29, 2009

EA-09-145

Mr. Gene St. Pierre
Vice President, North Region
Seabrook Nuclear Power Plant
NextEra Energy Seabrook, LLC
c/o Mr. Michael O'Keefe
P.O. Box 300
Seabrook, NH 03874

SUBJECT: REPLY TO NOTICE OF VIOLATION

Dear Mr. St. Pierre:

The purpose of this letter is to acknowledge receipt of your letter dated December 11, 2009, that responded to the Notice of Violation issued on November 12, 2009. The Notice of Violation was issued because you did not adequately establish measures to assure that regulatory requirements and the design basis for the B Emergency Diesel Generator (EDG) were correctly translated into specifications and instructions during modifications to the B EDG right bank turbocharger. In your letter you documented the corrective actions you completed to restore compliance with the regulations and to ensure similar violations did not occur.

Thank you for informing us of your corrective actions for this matter. Your actions in addressing these issues are subject to future NRC inspection activities.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and your response dated December 11, 2009, will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

If you have any questions or comments, please contact me at 610-337-5069.

Sincerely,

/RA/

Arthur L. Burritt, Chief
Projects Branch 3
Division of Reactor Projects

cc: Distribution via ListServ

EA-09-145

Mr. Gene St. Pierre
Vice President, North Region
Seabrook Nuclear Power Plant
NextEra Energy Seabrook, LLC
c/o Mr. Michael O'Keefe
P.O. Box 300
Seabrook, NH 03874

SUBJECT: REPLY TO NOTICE OF VIOLATION

Dear Mr. St. Pierre:

The purpose of this letter is to acknowledge receipt of your letter dated December 11, 2009, that responded to the Notice of Violation issued on November 12, 2009. The Notice of Violation was issued because you did not adequately establish measures to assure that regulatory requirements and the design basis for the B Emergency Diesel Generator (EDG) were correctly translated into specifications and instructions during modifications to the B EDG right bank turbocharger. In your letter you documented the corrective actions you completed to restore compliance with the regulations and to ensure similar violations did not occur.

Thank you for informing us of your corrective actions for this matter. Your actions in addressing these issues are subject to future NRC inspection activities.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and your response dated December 11, 2009, will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

If you have any questions or comments, please contact me at 610-337-5069.

Sincerely,
/RA/
Arthur L. Burrirt, Chief
Projects Branch 3
Division of Reactor Projects

SUNSI Review Complete: LC (Reviewer's Initials) **ML093630077**

DOCUMENT NAME: G:\DRP\BRANCH3\ENFORCEMENT\SEABROOK EDG\EA09145.DOC

After declaring this document "An Official Agency Record" it **will** be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP	RI/DRP	RI/ORA	RI/DRP
NAME	WRaymond/ALB for	LCline/ LC	DHolody/MMM for	ABurrirt/ALB
DATE	12/ 23/09	12/23 /09	12/23 /09	12/23 /09

OFFICIAL RECORD COPY