

50-247

File

April 1, 1971

R. C. DeYoung, Assistant Director for Pressurized Water Reactors, DRL
THRU: D. R. Muller, Chief, PWR Projects Branch #1, DRL

POTENTIAL REQUEST FOR FUEL LOADING, CONSOLIDATED EDISON COMPANY OF NEW YORK, INC., INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

CONFERENCE TELEPHONE CALL

A conference telephone call was conducted on March 27, 1971 regarding a potential request for fuel loading to be made to the Atomic Safety and Licensing Board at the Indian Point Unit 2 hearing. The applicant desires DRL concurrence with such a request. The following individuals participated.

Jack Grob	Con Ed
Robert Koppe	Con Ed
Leonard Trosten	LeBoeuf, Lamb, Leiby & MacRae
Robert Wiesemann	Westinghouse
Daniel R. Muller	DRL
Karl Kniel	DRL
Michael McCoy	DRL

The purpose of the call was to obtain DRL reaction to information supplied in writing by the applicant on March 19, 1971 with respect to his potential request for fuel loading.

On the basis of safety and security we stated three general requirements regarding plant completion which should be met before fuel loading operations should be initiated. They are:

1. All systems inside the containment should be complete and all construction activities of any kind in the containment should have been completed.
2. All systems outside of the containment directly connected to the primary systems should be complete.
3. All engineered safety features complete and operable including provisions for auxiliary electric power.

OFFICE ►						
SURNAME ►	8111140154 710401 ADOCK 05000247 LF					
DATE ►						