

January 28, 1970

K. Kniel  
Reactor Projects Branch #1, DRL  
THRU: *D* D. Thompson, Chief  
Operational Safety Branch, DRL

CONSOLIDATED EDISON, INDIAN POINT STATION, UNIT NO. 2, PLANT SECURITY  
DOCKET NO. 50-247

Ref: Questions from P. Morris to Consolidated Edison of Aug. *4*, 1969.

We have reviewed Consolidated Edison's provisions for plant security, as submitted in Section 12 of Supplement No. 2. As part of the referenced questions, the applicant was asked to describe what access the general public has to various portions of the building.

The applicant states that for the general public, "escorted tours are made to the plant during which visitors are shown the turbine hall and are permitted to view Central Control Room operations through a glass enclosed booth which projects into the west end of the control room." This control room is shared with Unit No. 1 and projects into the west end of the common control room. In addition we understand that the glass wall of this booth does not extend to the ceiling.

We conclude that the admission of the general public into the control room area is not a prudent practice in regard to the security of the control room area for Units 1 & 2.

*FR*  
F. R. Allenspach  
Operational Safety Branch, DRL

cc: D. J. Skovholt, DRL  
D. R. Muller, DRL

8111140504 700128  
ADOCK 05000247

OFFICE ▶	OSB: DRL	OSB: DRL					
SURNAME ▶	<i>FR</i> FR Allenspach	<i>DT</i> cl. D Thompson					
DATE ▶	1/28/70	1/28/70					