

APR 29 1969

R. S. Boyd, Assistant Director for Reactor Projects, DRL
THRU: S. Levine, Assistant Director for Reactor Technology, DRL

PRELIMINARY QUESTIONS ON INDIAN POINT 2 - DOCKET NO. 50-247

Attached are our preliminary questions on the Indian Point 2 project.

It should be noted that with regard to question sixteen Indian Point 2 by our calculations requires credit for methyl iodide removal to satisfy the guideline dose levels of 10 CFR 100. A 30 day thyroid dose reduction factor of approximately 11.2 is needed to meet the 300 rem thyroid limit.

1

RT-380A
E&RSTB:DRL:IS

P. W. Howe, Chief, Environmental
& Radiation Safety Technology Branch
Division of Reactor Licensing

Enclosure:
Prel. Questions-Indian Pt. 2

cc w/enclosure:
D. Muller, RP #1, DRL
K. Kniel, RP #1, DRL

8111230042 690429
ADOCK 05000247

OFFICE ▶	E&RSTB:DRL	E&RSTB:DRL	RT:DRL	RT:DRL		
SURNAME ▶	ISpickler:bc	P. W. Howe	R. DeYoung	S. Levine		
DATE ▶	4/28/69	4/29/69	4/25/69	4/28/69		