

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-247CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 38 to Facility Operating License No. DPR-26, issued to Consolidated Edison Company of New York, Inc. (the licensee), which revised Technical Specifications for operation of the Indian Point Nuclear Generating Unit No. 2 (the facility) located in Buchanan, Westchester County, New York. The amendment is effective as of the date of issuance.

The amendment deletes requirements in the Technical Specifications for part length control rods on the basis that they are not needed for reactor operation and their drop into the core could cause abnormal flux distribution and/or reactor shutdown.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

DISTRIBUTION:  
Docket  
ORB#4 Reading  
RIngram

Docket No. 50-247

MARCH 9 1978

Docketing and Service Section  
Office of the Secretary of the Commission

SUBJECT: CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies ( 12 ) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Other: Amdt. No. 38

Referenced documents have been provided PDR.

Division of Operating Reactors, ORB#4  
Office of Nuclear Reactor Regulation

Enclosure:  
As Stated

OFFICE →	ORB#4: DOR					
SURNAME →	RIngram:dn					
DATE →	3/9/78					

- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment transmitted by letter dated November 2, 1977, (2) Amendment No. 38 to License No. DPR-26, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. and at the White Plains Public Library, 100 Martine Avenue, White Plains, New York. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 6th day of March 1978.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief  
Operating Reactors Branch #1  
Division of Operating Reactors

[7590-01]

\* [Docket No. 50-247]

**CONSOLIDATED EDISON CO. OF NEW YORK,  
INC.****Issuance of Amendment to Facility Operating  
License**

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 38 to Facility Operating License No. DPR-26, issued to Consolidated Edison Company of New York, Inc. (the licensee), which revised Technical Specifications for operation of the Indian Point Nuclear Generating Unit No. 2 (the facility) located in Buchanan, Westchester County, N.Y. The amendment is effective as of the date of issuance.

The amendment deletes requirements in the Technical Specifications for part length control rods on the basis that they are not needed for reactor operation and their drop into the core could cause abnormal flux distribution and/or reactor shutdown.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR § 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment transmitted by letter dated November 2, 1977, (2) Amendment No. 38 to License No. DPR-26, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commissioner's Public Document Room, 1717 H Street NW., Washington, D.C. and at the White Plains Public Library, 100 Martine Avenue, White Plains, N.Y. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Md., this 6th day of March 1978.

For the Nuclear Regulatory Commission.

A. SCHWENCER,  
*Chief, Operating Reactors  
Branch No. 1, Division of Operating Reactors.*

[FR Doc. 78-6844 Filed 3-15-78; 8:45 am]

[7590-01]

[Docket Nos. 50-10, 50-237, 50-249, 50-254  
and 50-265]

**COMMONWEALTH EDISON CO. AND IOWA-  
ILLINOIS GAS AND ELECTRIC CO.****Issuance of Amendments to Facility Operating  
Licenses**

The U.S. Nuclear Regulatory Commission (the Commission) has issued an amendment each to Facility Operating License Nos. DPR-2, DPR-19, DPR-25, DPR-29, and DPR-30, issued to Commonwealth Edison Co. (and, in the matter of License Nos. DPR-29 and DPR-30, the Iowa-Illinois Gas and Electric Co.), which revised Technical Specifications for operation of each of the Dresden and Quad Cities Nuclear Power Stations (collectively referred to as the facilities). The Dresden Station consists of Unit Nos. 1, 2, and 3 and is located in Grundy County, Ill. The Quad Cities Station consists of Unit Nos. 1 and 2 and is located in Rock Island County, Ill. These amendments are effective as of their date of issuance.

The amendments consist of administrative changes to the Technical Specifications for the facilities that:

1. Deleted the requirement for an Annual Operating Report, while retaining the specific requirement for an Annual Operating Report of Occupational Exposure;
2. Modified the submittal date for the Monthly Operating Report to the 15th instead of the 10th of the month following the calendar month covered by the report; and
3. Deleted reference to respiratory protection equipment since this item is now covered by 10 CFR 20.103 of Part 20 of the Commission's regulations.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR § 51.5(d)(4) an environ-

mental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of the amendments.

For further details with respect to this action, see (1) the application for amendment dated December 6, 1977, (2) Amendment Nos. 24, 35, and 32 to License Nos. DPR-2, DPR-19, and DPR-25, (3) Amendment Nos. 44 and 42 to License Nos. DPR-29 and DPR-30, and (4) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street NW., Washington, D.C. and for those items relating to Dresden Unit Nos. 1, 2, and 3 at the Morris Public Library, 604 Liberty Street, Morris, Ill. 60450 and for those items relating to Quad Cities Unit Nos. 1 and 2 at the Moline Public Library, 504 17th Street, Moline, Ill. 60625. A single copy of items (2), (3), and (4) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, attention: Director, Division of Operating Reactors.

Dated at Bethesda, Md., this 1st day of March, 1978.

For the Nuclear Regulatory Commission.

DENNIS L. ZIEMANN,  
*Chief, Operating Reactors  
Branch No. 2, Division of Operating Reactors.*

[FR Doc. 78-6843 Filed 3-15-78; 8:45 am]

[7590-01]

[Docket No. 50-265]

**COMMONWEALTH EDISON CO. AND IOWA-  
ILLINOIS GAS AND ELECTRIC CO.****Issuance of Amendment to Facility Operating  
License**

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 43 to Facility Operating License No. DPR-30, issued to Commonwealth Edison Co. (acting for itself and on behalf of the Iowa-Illinois Gas and Electric Co.), which revised the license and Technical Specifications appended thereto for operation of the Quad Cities Nuclear Power Station Unit No. 2 (the facility) located in Rock Island County, Ill. The amendment is effective as of its date of issuance.

The amendment (1) authorized operation with additional 8 x 8 fuel assemblies; (2) incorporated revised MAPLHGR and MCPR limits in response to the plant specific analysis for reload 3, and (3) modified License Condition 3.C to reflect end-of-cycle scram reactivity conditions for reload 3.

The application for the amendment complies with the standards and re-

mz