JAN 4 1974

J. M. Hendrie, Deputy Director for Technical Review

TECHNICAL ASSISTANCE REQUEST NO. ORB-1-69
FILTER TESTING

Plant Name: Indian Point 2
Docket No.: 50-247
Licensing Stage: Licensed
Requesting Branch: Operating Reactors Branch #1
Project Manager: R. W. Woodurff
Requested Completion Date: January 15, 1974
Branches Involved: Accident Analysis Branch

By letter dated December 4, 1973, Consolidated Edison Company proposed changes to Technical Specification 4.5.II.C.2 for Indian Point 2. The proposed changes would permit testing of iodine filters in the containment ventilation system at lower values of temperature, pressure, and humidity than are now specified. By letter dated December 11, 1973, Berlin, Roisman, and Kessler, counsel for Citizens Committee for Protection of the Environment, commented on the purpose and adequacy of Consolidated Edison Company's application for the proposed changes.

Copies of existing Technical Specification 4.5.II.C.2, the application for the proposed changes, and Berlin, Roisman, and Kessler's letter are attached. Please review the application and provide recommendations for changes to Technical Specification 4.5.II.C.2 which would meet our regulatory requirements. We would like to have your recommendations by January 21, 1974.

Original Signed by
Donald J. Skovholt

Donald J. Skovholt
Assistant Director for
Operating Reactors
Directorate of Licensing

Enclosures:
1. Technical Specification 4.5.II.C.2
2. Application
3. Berlin, Roisman, and Kessler's letter

DISTRITUBION
Docket File
RP Reading File
Branch Reading File

cc w/enclosures:
B. Grimes
R. Zavadoski

8111140594 740104
ADOCK 05000247

cc w/o enclosures:

OFFICE	W. McDonald	T. J. Carter	L:ORB #1	L:ORB #1	L:ORB #1	L:OR
SURNAME	D. Skovholt	S. Teets	RWWoodurff:1	SATeets	RJSchemel	DJSKovholt
DATE	R. Schemel	R. Woodruff	1/3/74	1/6/74	1/4/74	1/4/74