

SEP 13 1972

Richard C. DeYoung, Assistant Director
for Pressurized Water Reactors
Directorate of Licensing

EVALUATION OF "SUMMARY REPORT OF SAFETY AND RELIEF VALVE INSTALLATION
AND RE-ANALYSIS FOR ASME CLASS 1 AND 2 SYSTEMS IN INDIAN POINT UNIT
NO. 2", JULY 13, 1972 (TAR-110)

Name: Indian Point Unit 2
Status: Operating License Hearing
Docket No.: 50-247
Branch: PWR#2
Project Leader: Karl Kniel

In accordance with your request, our Mechanical Engineering Branch,
Directorate of Licensing has reviewed the subject report. The
forcing functions and the dynamic and stress analysis methods and
procedures that were used are not described. We suggest that a
meeting be arranged with the applicant to provide the additional
information necessary to allow completion of our evaluation of
the subject report.

Org. Sgn. by DFL for

R. R. Maccary, Assistant Director
for Engineering
Directorate of Licensing

cc w/encl:
S. H. Hanauer, DRTA
J. M. Hendrie, L
K. Kniel, L
D. F. Lange, L
S. N. Hou, L
A. Giambusso, L
W. G. McDonald, L

Subject File

8111170112 720913
ADOCK 05000247

OFFICE	L:MEB <i>S. Hou</i>	L:MEB <i>DFLange</i>	L:AD/E <i>R. Maccary</i>			
SURNAME	SNHou:jm	DFLange	RMaccary			
DATE	9/12/72	9/12/72	9/12/72			