Carl L. Newman Vice President

Regulatory

File Cy.

Consolidated Edison Company of New York, Inc. 4 Irving Place, New York, N. Y. 10003 Telephone (212) 460-5133

December 6, 1974

Re: Indian Point Unit No. 2 AEC Docket No. 50 547 タルフ

Mr. George Lear, Chief Operating Reactors Branch #3 Directorate of Licensing U.S. Atomic Energy Commission Washington, D,C. 20545

Dear Mr. Lear:

As requested by your letter of November 4, 1974, we are submitting the remainder of the additional information identified by you as necessary to complete your review of our Emergency Core Cooling Analysis. Answers to all other applicable questions transmitted in that request, except Question 1b, were submitted to you by my letter dated December 2, 1974. This letter completes our response to your request for the information.

Very truly yours,

Vice President

Carl L. Newman

enc. hk

8111100197 741206 PDR ADOCK 05000247

PDR



12473

### Question No. 1b:

#### Received w/Ltr Dated 12-6-74

Regulatory

Provide justification for the following input parameters used in the ECCS evaluation model:

Passive Heat Sinks - Discuss the method of determining the passive containment heat sinks. Identify each heat sink by category (i.e., cable tray, equipment supports, floor grating, crane wall, etc.) and provide surface area, thickness, materials of construction, thermal conductivity and volumetric heat capacity, by component category used in the containment transient analysis code.

#### Response to Question No. 1b:

The basis and qualifications for determining the passive containment heat sinks are stipulated as follows:

- a. Design basis in Indian Point Unit No. 2 Containment Construction Drawings.
- b. Total surface areas are not direct results of a total detail take-off, but are extrapolations from segments.
- c. All support steel and structures are assumed to be fully exposed if not embedded in concrete.
- d. No differentiation has been allowed for painting or coatings of the steel.
- e. Quantities for exposed surface area of structural steel were developed on a tonnage basis and projected to an area by using a factor of 200 square feet of exposed steel per ton.

-1-

### Response to Question No. 1b: (Cont'd)

f. For structural material exposed on both sides to the accident atmosphere only one-half of the structure's thickness is used as a thickness input (e.g., framing, supports, restraints and miscellaneous steel).

In Table 1, a detailed compilation of heat sinks, categorized by function and thickness, and including surface area, and material of construction are presented. The thermal conductivity and volumetric heat capacity for each heat sink material contained in the Table 1 are compiled in Table 2.

If the tabulated structures in Table 1 are categorized by their thicknesses as they are in Table 1.2-2 of WCAP-8404, ECCS Acceptance Criteria Analysis, Indian Point Nuclear Generating Station Unit No. 2, the summations of their surface areas are equal to the totals of the surface areas used in the analysis of WCAP-8404. In the single instance of the exposed steel liner of the Containment Cylinder, the actual exposed steel given by Table 1 of this submittal is less than the surface area used in the analysis. The value for this area used in WCAP-8404 is therefore more conservative than the calculated actual area.

-2-

# TABLE 1

# Structural Heat Sinks

Heat Sink	Material	·	Area Ft. <sup>2</sup>	Thick	ness (in)	
Linings		. •				
Containment Cylinder	Steel-Line Lining Ove	ed Concrete er Insulation	54025 15940		3/8	
	Exposed S	teel Liner	380.85		•	-
Containment Dome	Steel-Lined Concrete		28613		1/2	
Containment Floor	Unlined Concrete		15000		12	
Refueling Canal	Lined Concrete		10000		3/8	•
Miscellaneous Concrete Structure	Unlined Concrete		61000		12 <sup>°°°</sup>	
Steel Structures					.* •	
Annulus Framing	Steel	163T 13.5T 90T	32600 2704 18000		3/8 Plate 3/4 3/8	* * *
Steam Generator Supports	Steel	316T 48T	63200 9600		3/4 3/8 Plate	* *
Pressurizer Support		13T	2600		3/8"	*
Reactor Coolant Pump Supports	· · · · · · · · · · · · · · · · · · ·	48T 16T 19T 22T	9600 3200 3800 4400		3/4 3/8 Plate 3/8 3/4	* * *

### TABLE 1 (Continued)

Heat Sink	Material	Area Ft. <sup>2</sup>	<u>Thickness (in)</u>
Crane Crane Rail	Steel 329T 9T	65800 1800	1/2 3/4 *
Miscellaneous Iron & Steel Handrails, Rails, Grating	50T	10000	1/8 *
Seismic Res- traints Hangers	100T	20000	1/2 *
Exposed Pipe	-	7948	1/4 *
Exposed Conduit	157	3000	1/8
Ductwork		22000	10 Ga. (.1382)
Accumulators		2992	1/2

\* Steel structures that are exposed on both sides. These are listed in WCAP-8404 in categoria of one-half of the thicknesses listed here.

. . . .

C)

## TABLE II

# Containment Heat Sink Thermodynamic Data

Materials	K (Btu/hr,-Ft.°F)	(Btu/Ft. <sup>3</sup> -°F)
Stainless Steel Liner Plate	8.6	56.35
Carbon Steel Liner Plate	26.0	56.35
Structural Concrete	0.8	28.8

K = Thermal Conductivity

6.5.25

ρCp = Volumetric Heat Capacity