




DEPARTMENT OF THE ARMY
COASTAL ENGINEERING RESEARCH CENTER
5201 LITTLE FALLS ROAD, N.W.
WASHINGTON, D.C. 20016

CEREN

21 November 1969

Mr. Roger S. Boyd
Asst. Director for Reactor Projects
Division of Reactor Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545



Dear Mr. Boyd:

Reference is made to your letters regarding Docket Nos. 50-247, 50-286, 50-342, and 50-343, Consolidated Edison Company of New York's proposed Indian Point Nuclear Generating Units No. 2 and No. 3, and Units No. 4 and No. 5 which are contiguous to Indian Point plant site.

Pursuant with our arrangements, Mr. R. A. Jachowski and Mr. B. R. Bodine of CERC have reviewed all pertinent information contained in the reports from the standpoint of establishment of a design water level. This included the review of the storm surge associated with the Probable Maximum Hurricane (PMH) and wind wave analysis.

We concur with the applicant's finding that the design water level should be 14.5 feet above the mean sea level datum for Units, Nos. 2, 3, 4 and 5. Although this value is acceptable, there are compensating errors in routing procedure employed.

If you have any further questions regarding this matter please let us know.

Sincerely yours,

Edward M. Willis
EDWARD M. WILLIS
Lieutenant Colonel, CE
Director

8111140214 691121
PDR ADOCK 05000247
PDR
A

3677