

UNIT NAME Indian Point Unit No. 2DATE December 6, 1974COMPLETED BY S. D. Julias

Performance General Supervisor Tel. # 914-592-9010

OPERATING STATUS

Ext. 231 at I.P.

1. REPORTING PERIOD: 0000,741101 THROUGH 2359,741130GROSS HOURS IN REPORTING PERIOD: 7202. CURRENTLY AUTHORIZED POWER LEVEL MWe 2758 MWe-NET 8733. POWER LEVEL TO WHICH RESTRICTED (IF ANY): 803 MWe-NET

4. REASONS FOR RESTRICTIONS (IF ANY):

Loss of circulating water flow through main turbine generator
condensers. No restriction on reactor power level.

	THIS MONTH	YR-TO-DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>644.2</u>	<u>4790.7</u>	<u>5991.7</u>
6. REACTOR RESERVE SHUTDOWN HOURS (5)	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON-LINE	<u>630.3</u>	<u>4517.75</u>	<u>5389.75</u>
8. UNIT RESERVE SHUTDOWN HOURS (6)	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL POWER GENERATED (MWH)	<u>1427937</u>	<u>9671815</u>	<u>10764103</u>
10. GROSS ELECTRICAL POWER GENERATED (MWH)	<u>436220</u>	<u>2991340</u>	<u>3313080</u>
11. NET ELECTRICAL POWER GENERATED (MWH)	<u>414915</u>	<u>2811309</u>	<u>3087290</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>89.5</u>	<u>59.8</u>	<u>51.3</u>
13. PLANT AVAILABILITY FACTOR (2)	<u>87.5</u>	<u>56.4</u>	<u>46.1</u>
14. PLANT CAPACITY FACTOR (3)	<u>66.0</u>	<u>40.2</u>	<u>30.3</u>
15. FORCED OUTAGE RATE (4)	<u>5.3</u>	<u>30.5</u>	<u>42.9</u>

16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE AND

DURATION OF EACH): Scheduled shutdown of approx. 3 days in December
to inspect and replace seismic restraints. Three week shut-
down scheduled in January for change in S.G. chemistry

17. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

18. PLANTS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED	REASON FOR DIFFERENCE
INITIAL CRITICALITY	_____	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	<u>N.A.</u>	_____
COMMERCIAL OPERATION	_____	_____	_____

(1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{GROSS HOURS IN REPORTING PERIOD}} \times 100$ (2) PLANT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON-LINE}}{\text{GROSS HOURS IN REPORTING PERIOD}} \times 100$ (3) PLANT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{CURRENTLY LICENSED POWER LEVEL} \times \text{GROSS HOURS IN REPORTING PERIOD}}$ (4) FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON-LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

(5) REACTOR RESERVE SHUTDOWN HOURS = THE DURATION IN HOURS THAT THE REACTOR WAS REMOVED FROM SERVICE FOR ADMINISTRATIVE OR OTHER REASONS BUT WAS AVAILABLE FOR OPERATION.

(6) UNIT RESERVE SHUTDOWN HOURS = THE DURATION IN HOURS THAT THE UNIT WAS REMOVED FROM SERVICE FOR ECONOMIC OR SIMILAR REASONS, BUT WAS AVAILABLE FOR OPERATION.

8111120488 741210
PDR ADDCK 05000247
PDR
R

UNIT Indian Point Unit No. 2

DATE December 6, 1974

COMPLETED BY S. D. Julias
Performance General Supervisor
Tel. # 914-592-9010 Ext. 231
at I.P.

DAILY PLANT POWER OUTPUT

MONTH November, 1974

<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>	<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>
1	<u>839</u>	25	<u>667</u>
2	<u>754</u>	26	<u>654</u>
3	<u>808</u>	27	<u>659</u>
4	<u>681</u>	28	<u>589</u>
5	<u>337</u>	29	<u>673</u>
6	<u>258</u>	30	<u>813</u>
7	<u>101</u>	31	<u>-</u>
8	<u>589</u>		
9	<u>18</u>		
10	<u>0</u>		
11	<u>431</u>		
12	<u>779</u>		
13	<u>421</u>		
14	<u>550</u>		
15	<u>789</u>		
16	<u>682</u>		
17	<u>671</u>		
18	<u>681</u>		
19	<u>674</u>		
20	<u>647</u>		
21	<u>695</u>		
22	<u>679</u>		
23	<u>625</u>		
24	<u>535</u>		

SUMMARY: Special three loop operation test performed. Also performed axial xenon transient test utilizing full and part length rods for control of axial flux difference.

UNIT NAME Indian Point Unit No. 2

DATE December 6, 1974

COMPLETED BY S. D. Julias

Performance General Supervisor
Tel. # 914-592-9010 Ext. 231 at I.P.

REPORT MONTH November, 1974

PLANT SHUTDOWNS

	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	COMMENTS
N/A	11/5/74	N/A	N/A	N/A	N/A	Reactor power reduced to 45% on 11/4/74 and held at this level for special three loop operation test.
54	11/6/74	F	4.5	A	C	Unit tripped via over temperature Δ temperature protection due to a shorted test lead on #21 loop hot leg R.T.D.
55	11/7/74	F	11.3	A	C	Unit tripped due to high drum level on #21 Steam Generator.
56	11/9/74	S	54	B	B	Outage for inspection of seismic pipe restraints.
57	11/13/74	F	15.5	A	C	Unit trip due to failure of No. 21 static inverter concurrent with periodic testing of the reactor protection system.
58	11/28/74	F	4.3	A	C	Unit trip via #21 Steam Generator SF/WF mismatch due to loss of #21 Main Boiler Feed Pump.

(1) REASON:
A-EQUIPMENT FAILURE (EXPLAIN)
B-MAINT. OR TEST
C-REFUELING
D-REGULATORY RESTRICTION
E-OPERATOR TRAINING AND
LICENSE EXAMINATION
F-ADMINISTRATIVE
G-OPERATIONAL ERROR
(EXPLAIN)

(2) METHOD:
A- MANUAL
B- MANUAL SCRAM
C- AUTOMATIC SCRAM