

From: cjheintz@firstenergycorp.com
Sent: Tuesday, December 15, 2009 3:08 PM
To: Sands, Stephen
Cc: kmnesser@firstenergycorp.com
Subject: Re: Relief Requests A-32 and A-33
Attachments: RR-A32 Page for NRC.pdf; RR-A33 Page for NRC.pdf

Stephen-

As requested, FENOC's response to the two NRC reviewer questions, in bold font, are as follows:

1. Section A1.4(d) of Relief Request RR-A33, Attachment 1, provides requirements for additional examinations when inservice examinations detect defects in overlaid dissimilar metal welds. However, Section A2.3 of Relief Request RR-A32, Attachment 2, does not contain the same requirements for the additional examinations as that of Relief Request RR-A33. Please explain why Relief Request RR-A32 does not contain the same requirements for the additional examinations.

FENOC Response: Request RR-A32 should have the same section as Request RR-A33, entitled "Additional Examinations." FENOC proposes to add the section to RR-A32. See the attached page from RR-A32 that depicts the proposed resolution.

2. Section A1.4(d) of Relief Request RR-A33, Attachment 1, references A1.4 (c) (4), which should be A1.4(c) (5). Please verify if the reference of A1.4(c) (4) is correct.

FENOC Response: The reference within Request RR-A33 should be "A1.4(c) (5)."
See the attached page from RR-A33 that depicts the proposed resolution.

(See attached file: RR-A32 Page for NRC.pdf) (See attached file: RR-A33 Page for NRC.pdf)

Please advise on the acceptability of these responses.

Cal Heintz
Fleet Licensing
Fleet Regulatory Affairs
FirstEnergy Nuclear Operating Company [FENOC]

440.280.5035 [office] 440.478.9845 [mobile]
CJHeintz@FirstEnergyCorp.com

"Sands, Stephen"
<Stephen.Sands@nr
c.gov>

To

12/15/2009 08:20
AM

"'kmnesser@firstenergycorp.com'"
<kmnesser@firstenergycorp.com>,
"'cjheintz@firstenergycorp.com'"
<cjheintz@firstenergycorp.com>

cc

Subject

Relief Requests A-32 and A-33

Kathy/Cal:

The reviewer had two follow-on questions that he would like you to respond to listed below:

1. Section A1.4(d) of Relief Request RR-A33, Attachment 1, provides requirements for additional examinations when inservice examinations detect defects in overlaid dissimilar metal welds. However, Section A2.3 of Relief Request RR-A32, Attachment 2, does not contain the same requirements for the additional examinations as that of Relief Request RR-A33. Please explain why Relief Request RR-A32 does not contain the same requirements for the additional examinations.

2. Section A1.4(d) of Relief Request RR-A33, Attachment 1, references A1.4 (c) (4), which should be A1.4(c) (5). Please verify if the reference of A1.4(c) (4) is correct.

Please ask the licensee to respond, by email, to the above two questions by today, 12-15-09 if possible.

Regards,
Stephen Sands
Division of Operating Reactors
Davis-Besse & Perry Project Manager
Licensing Project Branch 3-2
Phone: 301-415-3154
E-mail: Stephen.Sands@nrc.gov

The information contained in this message is intended only for the personal and confidential use of the recipient(s) named above. If the reader of this message is not

the intended recipient or an agent responsible for delivering it to the intended recipient, you are hereby notified that you have received this document in error and that any review, dissemination, distribution, or copying of this message is strictly prohibited. If you have received this communication in error, please notify us immediately, and delete the original message.

E-mail Properties

Mail Envelope Properties (OFF6274A98.976EA7B1-ON8525768D.006CE661-8525768D.006E92A4)

Subject: Re: Relief Requests A-32 and A-33
Sent Date: 12/15/2009 3:08:03 PM
Received Date: 12/15/2009 3:08:03 PM
From: cjheintz@firstenergycorp.com

Created By: cjheintz@firstenergycorp.com

Recipients:

Stephen.Sands@nrc.gov (Sands, Stephen)
Tracking Status: None
kmnesser@firstenergycorp.com (kmnesser@firstenergycorp.com)
Tracking Status: None

Post Office:

FirstEnergyCorp.com

Files	Size	Date & Time
MESSAGE	53158	12/15/2009
RR-A32 Page for NRC.pdf	23723	
RR-A33 Page for NRC.pdf	18338	

Options

Expiration Date:
Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal

Recipients received: