

Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402-2801

December 30, 2009

10 CFR 50.46

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555-0001

> Watts Bar Nuclear Plant, Unit 1 Facility Operating License No. NPF-90 NRC Docket No. 50-390

Subject: Watts Bar Nuclear Plant Unit 1 - Emergency Core Cooling System Evaluation Model Changes - Annual Notification and Reporting

Reference: Watts Bar Nuclear Plant (WBN) Unit 1 - Emergency Core Cooling System (ECCS) Evaluation Model Changes - Annual Notification and Reporting, dated July 2, 2008.

This letter provides the annual update report required by 10 CFR 50.46. The enclosed information addresses changes or errors in the WBN ECCS evaluation model that affect calculation of peak clad temperature (PCT). This report covers the period from WBN's last 10 CFR 50.46 annual report, which was submitted by the referenced letter, through September 2009. WBN's ECCS evaluation model is contractually maintained by Westinghouse Electric Company, who provided the enclosed updates.

The changes to the model that have been made since our last update are described in Enclosure 1. The changes listed in Enclosure 1 had no impact on the calculated PCT for WBN. This update includes the 20°F Cycle 9-specific penalty previously identified in the referenced letter. The PCT margin allocations resulting from the changes since the Analysis of Record are summarized in the rackup sheets provided in Enclosure 2, which includes both Cycle 9 and general rackup sheets.

ADD1 NRR

U.S. Nuclear Regulatory Commission Page 2 December 30, 2009

There are no regulatory commitments associated with this submittal. Please direct any questions concerning this matter to Kevin Casey, Senior Project Manager, at (423) 751-8523.

Respectfully,

Send FOR

农. M. Krich Vice President Nuclear Licensing

Enclosures:

- 1. Changes to the Evaluation Model
- 2. Rack-Up Sheets

cc (Enclosures):

NRC Regional Administrator – Region II

NRC Resident Inspector - Watts Bar Nuclear Plant

ENCLOSURE 1

Changes to Emergency Core Cooling System Evaluation Model

ERRORS IN REACTOR VESSEL LOWER PLENUM SURFACE AREA CALCULATIONS (Non-Discretionary Change)

Background

Two errors were discovered in the calculations of reactor vessel lower plenum surface area. The corrected values have been evaluated for impact on current licensing-basis analysis results and will be incorporated on a forward-fit basis. These changes represent a closely-related group of Non-Discretionary Changes in accordance with Section 4.1.2 of WCAP-13451.

Affected Evaluation Model(s)

1981 Westinghouse Large Break LOCA Evaluation Model with BASH 1985 Westinghouse Small Break LOCA Evaluation Model with NOTRUMP

١

Estimated Effect

The differences in vessel lower plenum surface area are relatively minor and would be expected to produce a negligible effect on large and small break LOCA analysis results, leading to an estimated PCT impact of 0°F for 10 CFR 50.46 reporting purposes.

DISCREPANCY IN METAL MASSES USED FROM DRAWINGS (Non-Discretionary Change)

Background

Discrepancies were discovered in the use of metal masses from drawings. The updated reactor vessel metal masses and fluid volumes have been evaluated for impact on current licensing-basis analysis results and will be incorporated on a forward-fit basis. These changes represent a closely-related group of Non-Discretionary Changes in accordance with Section 4.1.2 of WCAP-13451.

Affected Evaluation Model(s)

1981 Westinghouse Large Break LOCA Evaluation Model with BASH 1985 Westinghouse Small Break LOCA Evaluation Model with NOTRUMP

Estimated Effect

The differences in the reactor vessel metal mass and fluid volume are relatively minor and would be expected to produce a negligible effect on large and small break LOCA analysis results, leading to an estimated PCT impact of 0°F for 10 CFR 50.46 reporting purposes.

GENERAL CODE MAINTENANCE (Discretionary Change)

Background

Various changes have been made to enhance the usability of the codes and to help preclude errors in analyses. This includes items such as modifying input variable definitions, units, and defaults; improving the input diagnostic checks; enhancing the code output; optimizing active coding; and, eliminating inactive coding. These changes represent Discretionary Changes that will be implemented on a forward-fit basis in accordance with Section 4.1.1 of WCAP-13451.

Affected Evaluation Model(s)

1981 Westinghouse Large Break LOCA Evaluation Model with BASH 1985 Westinghouse Small Break LOCA Evaluation Model with NOTRUMP

Estimated Effect

The nature of these changes leads to an estimated PCT impact of 0°F.

)

GENERAL CODE MAINTENANCE (Discretionary Change)

Background

A number of coding changes were made as part of normal code maintenance. Examples include additional information in code outputs, improved automation and diagnostics in the codes, increased code dimensions, and general code cleanup. All of these changes are considered to be Discretionary changes in accordance with Section 4.1.1 of WCAP-13451.

Affected Evaluation Model(s)

1996 Westinghouse Best Estimate Large Break LOCA Evaluation Model 1999 Westinghouse Best Estimate Large Break LOCA Evaluation Model, Application to PWRs with Upper Plenum Injection 2004 Westinghouse Realistic Large Break LOCA Evaluation Model Using ASTRUM

Estimated Effect

The nature of these changes leads to an estimated PCT impact of 0°F for 10 CFR 50.46 reporting purposes.

HOTSPOT BURST TEMPERATURE LOGIC ERRORS (Non-Discretionary Change)

Background

The HOTSPOT code has been updated to incorporate the following corrections to the burst temperature logic: (1) change the rod internal pressure used to calculate the cladding engineering hoop stress from the value in the previous time step to the value in the current time step; (2) revise the average cladding heat-up rate calculation to reset selected variables to zero at the beginning of each trial and use the instantaneous heat-up rate when fewer than five values are available; and, (3) reflect the assumed saturation of ramp rate effects above 28°C/s for Zircaloy-4 cladding from Equation 7-66 of Reference 1. These changes represent a closely-related group of Non-Discretionary Changes in accordance with Section 4.1.2 of WCAP-13451.

Affected Evaluation Model(s)

1

1996 Westinghouse Best Estimate Large Break LOCA Evaluation Model 1999 Westinghouse Best Estimate Large Break LOCA Evaluation Model, Application to PWRs with Upper Plenum Injection 2004 Westinghouse Realistic Large Break LOCA Evaluation Model Using ASTRUM

Estimated Effect

Sample calculations for each change showed no effect on peak cladding temperature, leading to an estimated impact of 0°F for 10 CFR 50.46 reporting purposes.

Reference(s)

1. WCAP-12945-P-A, Volume 1 (Revision 2) and Volumes 2-5 (Revision 1), "Code Qualification Document for Best Estimate LOCA Analysis," S. M. Bajorek et al., March 1998.

CCFL GLOBAL VOLUME ERROR (Non-Discretionary Change)

Background

An error was identified during the course of a recent Best Estimate Large Break LOCA analysis in which the volume between the core barrel and the baffle plates in the CCFL region above the active fuel length was modeled incorrectly. The corrected values have been evaluated for impact on the current licensing-basis analysis results. This error represents a non-discretionary change in accordance with Section 4.1.2 of WCAP-13451.

1

Affected Evaluation Model(s)

1996 Westinghouse Best Estimate Large Break LOCA Evaluation Model 2004 Westinghouse Realistic Large Break LOCA Evaluation Model Using ASTRUM

Estimated Effect

The CCFL global volume modeling error has been generically evaluated to have a negligible impact on PCT for affected analyses and a penalty of 0 °F is assigned.

DISCREPANCY IN METAL MASSES USED FROM DRAWINGS (Non-Discretionary Change)

Background

Discrepancies were discovered in the use of Lower Support Plate (LSP) metal masses from drawings. The updates LSP metal masses have been evaluated for impact on current licensing-basis analysis results and will be incorporated on a forward-fit basis. These changes represent a closely-related group of Non-Discretionary Changes in accordance with Section 4.1.2 of WCAP-13451.

Affected Evaluation Model(s)

1996 Westinghouse Best Estimate Large Break LOCA Evaluation Model
1999 Westinghouse Best Estimate Large Break LOCA Evaluation Model, Application to PWRs with
Upper Plenum Injection
2004 Westinghouse Realistic Large Break LOCA Evaluation Model Using ASTRUM

SECY UPI WCOBRA/TRAC Large Break LOCA Evaluation Model

Estimated Effect

The Lower Support Plate mass error is relatively minor and would be expected to have a negligible effect on the Best-Estimate large break LOCA analysis results, leading to an estimated PCT impact of 0°F for 10 CFR 50.46 reporting purposes.

î

ENCLOSURE 2

(

0

Peak Clad Temperature Rackup Sheets

J

Analysis Date:

8/1/98

Plant Name:Watts Bar Unit 1Utility Name:Tennessee Valley Authority

~

Analysis Information

<u>COD (19</u>96)

<u>EM:</u>

Cycle 9, RSG

Limiting Break Size: Guillotine

Composite

1

FQ:	2.5	FdH:	1.65	_	
Fuel:	Vantage +	SGTP (%):	12		
Notes:	Mixed Core - V	antage + / Performance	+ / RFA-2		
				Clad Tam	n (°F)
LICEN	SING BASIS			Clau I chi	Р(Г)
	Analysis-Of-Reco	rd PCT			1892
PCT AS	SSESSMENTS (D	elta PCT)			
A	A. PRIOR ECCS I	MODEL ASSESSM	ENTS		-4
	2 . MONTECH	Decay Heat Uncertainty	Error		4
	3 . Input Error	Resulting in Incomplete S	olution Matrix		0
	4 . Tavg Bias I	Error			8
	5 . Revised Bl	owdown Heatup Uncertair	ty Distribution		5
	6 . HOTSPOT	Fuel Relocation Error			65
E	B. PLANNED PL 1 . Accumulate	ANT MODIFICATI	ON EVALUATION	S	-131
	2 . Increased A	ccumulator Temperature	Range Evaluation		4
	3.1.4% Uprat	e Evaluation	0		12
	4 Increased S	troke Time for the ECCS	Valves		0
	5 . Replacement	nt Steam Generators (D3 t	o 68AXP)		-10
	6 . PMID Viol	ation Evaluation			20
C	C. 2008 ECCS MC	DEL ASSESSMEN	TS		0
Ι	D. OTHER 1 . None				0
L	LICENSING BAS	IS PCT + PCT ASS	ESSMENTS	PCT =	1865

Plant Name:	Watts Bar Unit 1
Utility Name:	Tennessee Valley Authority

Cycle 9, RSG

Guillotine

Limiting Break Size:

Reflood 1

Analysis InformationEM:COD (1996)Analysis Date:8/1/98FQ:2.5FdH:1.65Fuel:Vantage +SGTP (%):12Notes:Mixed Core - Vantage + / Performance + / RFA-2

	Clad Te	mp (°F)
LICENSING BASIS		
Analysis-Of-Record PCT		1656
PCT ASSESSMENTS (Delta PCT)		
A. PRIOR ECCS MODEL ASSESSMENTS 1 . Vessel Channel DX Error		56
2 . MONTECF Decay Heat Uncertainty Error		4
3 . Input Error Resulting in Incomplete Solution Matrix		60
4 . Tavg Bias Error		8
5 . Revised Blowdown Heatup Uncertainty Distribution		5
6 . HOTSPOT Fuel Relocation Error		0
B. PLANNED PLANT MODIFICATION EVALUATIONS 1 . Accumulator Line/Pressurizer Surge Line Data Evaluation		-37
2 . Increased Accumulator Temperature Range Evaluation		4
3 . 1.4% Uprate Evaluation		12
4 . Increased Stroke Time for the ECCS Valves		0
5 . Replacement Steam Generators (D3 to 68AXP)		-50
6 . PMID Violation Evaluation		20
C. 2008 ECCS MODEL ASSESSMENTS		0
D. OTHER 1 . None		0
LICENSING BASIS PCT + PCT ASSESSMENTS	PCT =	1738

Plant Name:	Watts Bar Unit 1
Utility Name:	Tennessee Valley Authority

Cycle 9, RSG

Reflood 2

.

Analysis Information

,

EM:	<u>COD (19</u> 96)	Analysis Date:	8/1/98	Limiting Break Size	e: Guillotine
FQ:	2.5	FdH:	1.65	-	
Fuel:	Vantage +	SGTP (%):	12		
Notes:	Mixed Core - Vantage -	+ / Performance + /	RFA-2		
				Clad Town	(9E)
LICENSI	NG BASIS			Ciau Temp	(" F)
Aı	nalysis-Of-Record PC	Г			1892
PCT ASS	ESSMENTS (Delta PC	CT)			
А.	PRIOR ECCS MODE	L ASSESSMEN	TS		
	I . Vessel Channel DX	Error			-4
	2 . MONTECF Decay	Heat Uncertainty Erro	r		4
	3 . Input Error Resultin	g in Incomplete Soluti	on Matrix		0
	4 . Tavg Bias Error				8
	5 . Revised Blowdown	Heatup Uncertainty D	istribution		5
	6 . HOTSPOT Fuel Rel	location Error			65
В.	PLANNED PLANT M	IODIFICATION	EVALUATIONS		
	1 . Accumulator Line/P	ressurizer Surge Line	Data Evaluation		-131
	2 . Increased Accumula	tor Temperature Rang	e Evaluation		4
	3 . 1.4% Uprate Evalua	tion			12
	4 . Increased Stroke Tit	ne for the ECCS Valv	es		0
	5 . Replacement Steam	Generators (D3 to 68.	AXP)	-	-10
	6 . PMID Violation Eva	aluation			20
С.	2008 ECCS MODEL A	ASSESSMENTS			0
D.	OTHER 1 . None				0
LI	CENSING BASIS PCT	r + PCT ASSESS	SMENTS	PCT =	865

•

Plant Name:	Watts Bar Unit 1
Utility Name:	Tennessee Valley Authority

Analysis Information

1

RSG

Composite

<u>EM:</u>	COD (1996)	Analysis Date:	8/1/98	Limiting Break Size	: Guillotine
FQ:	2.5	FdH:	1.65		
Fuel:	Vantage +	SGTP (%):	12		
Notes:	Mixed Core - Vant	age + / Performance + /	RFA-2		
				Clad Temp	(° F)
LICENS	ING BASIS			Clau Temp	(
А	nalysis-Of-Record	РСТ		1	892
PCT ASS	SESSMENTS (Delt	a PCT)			
A.	PRIOR ECCS MO	DEL ASSESSMEN	TS		•
	1 . Vessel Channe	DX Error			-4
	2 . MONTECF D	ecay Heat Uncertainty Erro	r		4
	3 . Input Error Re	sulting in Incomplete Solut	ion Matrix		0
	4 . Tavg Bias Erro		8		
	5 . Revised Blowd	łown Heatup Uncertainty D	Distribution		5
	6 . HOTSPOT Fu	el Relocation Error			65
B.	PLANNED PLAN	T MODIFICATION	EVALUATIONS Data Evaluation	;	131
	2 . Increased Accu	umulator Temperature Rang	ge Evaluation		4
	3 . 1.4% Uprate E	valuation			12
	4 Increased Strol	ce Time for the ECCS Valu	ves		0
	5 . Replacement S	team Generators (D3 to 68	AXP)		-10
C.	2008 ECCS MOD	EL ASSESSMENTS			0
D	OTHER 1 . None				0
LI	CENSING BASIS	PCT + PCT ASSESS	SMENTS	PCT = 1	845

X

Plant Name:	Watts Bar Unit 1
Utility Name:	Tennessee Valley Authority

Analysis Information

RSG

Reflood 1

1

.

<u>EM:</u>	<u>COD (19</u> 96)	Analysis Date:	8/1/98	Limiting Break Size:	Guillotine
FQ:	2.5	FdH:	1.65	-	
Fuel:	Vantage +	SGTP (%):	12		
Notes:	Mixed Core - Vant	age + / Performance + /	RFA-2		
				Clad Temp (9 F)
LICENS	ING BASIS			Chau Temp (•)
А	nalvsis-Of-Record	РСТ		16	56
PCT ASS	SESSMENTS (Delt	a PCT)			
А.	PRIOR ECCS MO	DDEL ASSESSMEN	TS		
	1 . Vessel Channe	I DX Error			56
	2 . MONTECF D	ecay Heat Uncertainty Erro	r		4
	3 . Input Error Re	sulting in Incomplete Solut	ion Matrix		60
	4 . Tavg Bias Erro	٦r			8
	5 . Revised Blowd	lown Heatup Uncertainty E	Distribution		5
	6 . HOTSPOT Fu	el Relocation Error	,		0
B.	PLANNED PLAN	T MODIFICATION	EVALUATIO	ONS	
	1 . Accumulator L	.ine/Pressurizer Surge Line	Data Evaluation		37
	2 . Increased Accu	umulator Temperature Rang	ge Evaluation		4
	3 . 1.4% Uprate E	valuation			12
	4 . Increased Strol	ke Time for the ECCS Valv	res		0
	5 . Replacement S	team Generators (D3 to 68	AXP)	-	50
C.	2008 ECCS MOD	EL ASSESSMENTS			0
	I. None				U
D.	OTHER 1 . None				0
	CENSINC BASIS	DOT + DOT ASSES	SMENTS	$\mathbf{PCT} = 17$	18
1.1	CENSING DASIS	I U I T I UI ABBES	3141121N 1 (3	$\mathbf{I} \mathbf{C} \mathbf{I} = \mathbf{I} \mathbf{I}$	10

¥

Plant Name:	Watts Bar Unit 1
Utility Name:	Tennessee Valley Authority

Analysis Information

,

RSG

1

Reflood 2

1

<u>EM:_</u>	<u>COD (19</u> 96)	Analysis Date:	8/1/98	Limiting Break Size	: Guillotine
FQ:	2.5	FdH:	1.65		
Fuel:	Vantage +	SGTP (%):	12		
Notes:	Mixed Core - Vant	age + / Performance + /	RFA-2		
				Clad Temp	(°F)
LICENS	SING BASIS			Clau Temp	(1)
A	Analysis-Of-Record	РСТ		1	892
PCT AS	SESSMENTS (Delt	a PCT)			
Α	. PRIOR ECCS MO	DDEL ASSESSMEN	TS		
	1 . Vessel Channe	DX Error			-4
	2 . MONTECF D	ecay Heat Uncertainty Erro	r		4
	3 . Input Error Re	sulting in Incomplete Solut	ion Matrix		0
	4 . Tavg Bias Erro	pr			8
	5 . Revised Blowd	lown Heatup Uncertainty D	Distribution		5
	6 . HOTSPOT Fu	el Relocation Error			65
B	PLANNED PLAN	T MODIFICATION	EVALUATIONS		
	I . Accumulator L	ine/Pressurizer Surge Line	Data Evaluation		131
	2 . Increased Accu	imulator Temperature Rang	ge Evaluation		4
	3 . 1.4% Uprate E	valuation			12
	4 . Increased Strol	e Time for the ECCS Valv	res		0
	5 . Replacement S	team Generators (D3 to 68	AXP)		-10
С	. 2008 ECCS MOD	EL ASSESSMENTS			0
D	. OTHER 1 . None				0
L	ICENSING BASIS	PCT + PCT ASSES	SMENTS	PCT = 1	845

Westinghouse LOCA Peak Clad Temperature Summary for Appendix K Small Break

Plant Na	ame:	Watts Ba	r Unit 1				RSG
Utility Name:		Tennesse	e Valley Authority	,			
Analysis	Informati	on					
<u>EM:</u>	NOTE	RUMP	Analysis Date:	5/17/04	Limiting Break S	ize: 4 inch	
FQ:	2.5		FdH;	1.65	-		
Fuel:	RFA-2	2	SGTP (%):	12			
Notes:	Mixed	Core - Vant	tage + / Performance + /	RFA-2			
				Clad Tem	р (°F)		
LICENS	SING BA	SIS				-	
I	Analysis-	Of-Record	РСТ			1132	
PCT AS	SESSMI	ENTS (Delt	ta PCT)				
A	. PRIOR	ECCS MO	DDEL ASSESSMEN	TS			
	1.3	None				0	
В	. PLANN	IED PLAN	T MODIFICATION	EVALUATION	IS		
	1.	Increased Stro	ke Time for the ECCS Valv	ves		0	
C	C. 2008 E	CCS MOD	EL ASSESSMENTS				
	1.1	None				0	
Ľ	D. OTHE	R					
	1.	Leaking SIS R	telief Valve			120	
L	ICENSI	NG BASIS	PCT + PCT ASSES	SMENTS	PCT =	1252	

•

.

١