

50-247 INDIAN POINT 2 CEC
MISCELLANEOUS APPLICANT CORRESPONDENCE
June 1, 1990 THRU 3/31/91

Docket Nos. 50-247

MAR 21 1991

Mr. Stephen B. Bram
Vice President, Nuclear Power
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, New York 10511

Dear Mr. Bram:

SUBJECT: OPERATIONAL EVENTS WHILE SHUTDOWN

The NRC has just issued Information Notice 91-22, "Four Plant Outage Events Involving Loss of AC Power or Coolant Spills," which addresses recent events that occurred during shutdown operations.

The chief purpose of this information notice is to notify each licensee that the high rate of precursor events to loss of decay heat removal during shutdown is a source of concern to the NRC. All of the events discussed in this information notice occurred during a one-week period in March 1991. Because of the potential for loss of a critical safety function in these and similar events, I believe a high level of management attention is required in the planning, coordination, and execution of shutdown operations.

While this information notice does not require specific licensee action or response, I urge you to give this important matter your personal attention.

Sincerely,

Original signed by
Thomas E. Murley

Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDI-1 Reading
~~S. Vogan~~
E. Greenman, Acting
C. Vogan
F. Williams

OGC
E. Jordan
ACRS (10)
C. Hehl

OFC	:LA:PDI-1	:D:NR	:	:	:
NAME	:CVogan	:TMurley	:	:	:
DATE	:3/20/91	:3/ /91	:	:	:

OFFICIAL RECORD COPY
Document Name: UTILITY LETTERS

NRC FILE CENTER COPY

MA 4/wb



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 21 1991

Docket Nos. 50-247

Mr. Stephen B. Bram
Vice President, Nuclear Power
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, New York 10511

Dear Mr. Bram:

SUBJECT: OPERATIONAL EVENTS WHILE SHUTDOWN

The NRC has just issued Information Notice 91-22, "Four Plant Outage Events Involving Loss of AC Power or Coolant Spills," which addresses recent events that occurred during shutdown operations.

The chief purpose of this information notice is to notify each licensee that the high rate of precursor events to loss of decay heat removal during shutdown is a source of concern to the NRC. All of the events discussed in this information notice occurred during a one-week period in March 1991. Because of the potential for loss of a critical safety function in these and similar events, I believe a high level of management attention is required in the planning, coordination, and execution of shutdown operations.

While this information notice does not require specific licensee action or response, I urge you to give this important matter your personal attention.

Sincerely,

A handwritten signature in black ink, appearing to read "T. Murley", with a large, sweeping flourish underneath.

Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Stephen B. Bram
Consolidated Edison Company
of New York, Inc.

Indian Point Nuclear Generating Station
Units 1/2

cc:

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. Charlie Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Mr. Peter Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Charles W. Jackson
Manager of Nuclear Safety and
Licensing
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, New York 10511

Mr. Walter Stein
Secretary - NFSC
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 38
Buchanan, New York 10511

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Brent L. Brandenburg
Assistant General Counsel
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003