



Westinghouse Electric Company
Nuclear Power Plants
P.O. Box 355
Pittsburgh, Pennsylvania 15230-0355
USA

U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, D.C. 20555

Direct tel: 412-374-6206
Direct fax: 724-940-8505
e-mail: sisk1rb@westinghouse.com

Your ref: Docket No. 52-006
Our ref: DCP_NRC_002723

December 28, 2009

Subject: AP1000 Response to Request for Additional Information (SRP 10)

Westinghouse is submitting a response to the NRC request for additional information (RAI) on SRP Section 10. This RAI response is submitted in support of the AP1000 Design Certification Amendment Application (Docket No. 52-006). The information included in this response is generic and is expected to apply to all COL applications referencing the AP1000 Design Certification and the AP1000 Design Certification Amendment Application.

Enclosure 1 provides the response for the following RAI(s):

RAI-SRP10.2-SBPA-02 R3

Questions or requests for additional information related to the content and preparation of this response should be directed to Westinghouse. Please send copies of such questions or requests to the prospective applicants for combined licenses referencing the AP1000 Design Certification. A representative for each applicant is included on the cc: list of this letter.

Very truly yours,

for/ John J. DeBlasio

Robert Sisk, Manager
Licensing and Customer Interface
Regulatory Affairs and Standardization

/Enclosure

1. Response to Request for Additional Information on SRP Section 10

cc: D. Jaffe - U.S. NRC 1E
E. McKenna - U.S. NRC 1E
P. Kallen - U.S. NRC 1E
P. Buckberg - U.S. NRC 1E
T. Spink - TVA 1E
P. Hastings - Duke Power 1E
R. Kitchen - Progress Energy 1E
A. Monroe - SCANA 1E
P. Jacobs - Florida Power & Light 1E
C. Pierce - Southern Company 1E
E. Schmiech - Westinghouse 1E
G. Zinke - NuStart/Entergy 1E
R. Grumbir - NuStart 1E
P. Loza - Westinghouse 1E

ENCLOSURE 1

Response to Request for Additional Information on SRP Section 10

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

RAI Response Number: RAI-SRP10.2-SBPA-02
Revision: 3

Question:

With respect to the diversity of AP1000 DCD turbine overspeed control system, in its earlier request for additional information (RAI-TR86-SBPB-01, Item 3), the NRC staff requested the applicant to provide further information for a comparison of the reliability of the proposed turbine overspeed protection capability to the reliability that is afforded by the diverse capability that exists for existing plants. In its response, in a letter dated July 27, 2007, Westinghouse stated, "Another degree of diversity is provided by the software based trip that takes the speed reading from the I/O modules and applies control builder logic to determine the trip function which is then output via separate relay modules." Westinghouse response was not specific enough whether this applies to the primary overspeed trip of 110 percent and/or the emergency backup overspeed trip of 111 percent. Further, nothing else was stated in the DCD markup (TR-86) or in the rest of the above RAI response that would provide further details of the software configuration for the overspeed trip system. The NRC staff's concern is that if both the 110 percent and 111 percent overspeed trips use the same software, then a common cause failure (CCF) could render both systems inoperable. Therefore, with respect to defense against CCF for design diversity, and also to meet the guidance provided in SRP 10.2, Part III, "REVIEW PROCEDURES," Subsection 2.A where it states, "The design of the in-depth defense provided by the turbine generator protection system to preclude excessive overspeeds should include diverse protection means," the staff requests additional information and justification relating to the diversity of the turbine overspeed control system for AP1000 DCD, since it replaces the current mechanical overspeed system.

Westinghouse Response: (Revision 0)

In this and previous RAI-TR86-SBPB-01, Item 3, the NRC staff requested that Westinghouse to provide additional information on the diversity of the electronic replacement of the mechanical 110% overspeed trip with emergency 111% trip.

Westinghouse believes that the original design approach using the Ovation speed detector module firmware for both trips in parallel with Ovation controller software based logic provides a level of redundancy and diversity at least equivalent to the recommendations for turbine overspeed protection found in Part III of the Standard Review Plan (NUREG-0800) Section 10.2. However, Westinghouse has decided to commit to implementing the two overspeed trips using diverse (hardware and software/firmware) electronic means (i.e. one of the trips will not be implemented using the Ovation speed detector module), such that the 110% and 111% trips are not susceptible to a common cause software failure that would render them both inoperable.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Additional Westinghouse Response based on NRC comments at 3/18/09 meeting: (Revision 1)

Westinghouse will provide a Diverse Electronic Overspeed Protection System, which will prevent any single-failure and common cause failure from occurring. Diversity will be achieved by using a second electronic Overspeed Protection System (diverse hardware and software/firmware) in place of the mechanical trip mechanism, and the Ovation System for back-up overspeed protection. The circuitry of these systems and their control signals will be isolated and independent of each other. The Diverse Overspeed Protection System will be located in the Emergency Trip System cabinet drop (for tripping the turbine at 110% of rated speed), while the Ovation (back-up) System will be located in the Operator Automatic (OA) cabinet drop and will trip the turbine at 111% of rated speed.

Both systems will use a set of magnetic pickups for sensing speed and each set will be mounted on a separate bracket. Active magnetic probes will be used on the Ovation System and the Diverse Overspeed Protection System will use passive magnetic probes.

The overspeed trips are discussed in DCD Section 10.2.2.5.3, "Overspeed Trip Functions and Mechanisms." (The AP1000 uses trip setpoints of 110 and 111 percent, rather than the 111 and 112 percent indicated in the SRP.) Words are added in the DCD markup below containing text similar to that in the SRP, to clarify in the DCD that diversity exists. Also, an ITAAC is added to confirm the design acceptance criteria (DAC) of diverse hardware/firmware/software between the two overspeed trips.

The overspeed protection system will function for all abnormal conditions, including a single failure of any component or subsystem.

SRP 10.2, part III-2-D indicates that an independent and redundant backup electrical overspeed trip circuit senses the turbine speed by magnetic pickup and closes all valves associated with speed control at approximately 112 percent of rated speed. The circuitry is reviewed to confirm that the control signals from the two systems are isolated from, and independent of, each other.

Additional NRC request via 7/15 email: (Revision 2)

Open Items OI-SRP10.2-SBPA-01 and OI-SRP10.2-SBPA-02b appear to have been properly addressed with the RAI-SRP10.2-SBPA-02 R1 response ("AP1000 Response to Request for Additional Information (SRP 10)," DCP_NRC_002530, June 12, 2009). Therefore, these two open items should be considered closed.

However, this same RAI response does add an ITAAC, but this proposed ITAAC does not address the applicant's commitment to provide adequate diversity between the two electrical overspeed trips. Therefore, OI-SRP10.2-SBPA-02a is still an open item.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

If Westinghouse would add an ITAAC item which would have ITAAC Acceptance Criteria wording to the effect of:

“A report exists that shows that the two turbine electrical overspeed protection systems have diverse hardware and software/firmware.”

then the [RAI-SRP10.2-SBPA-02 design commitment stated by applicant] design alternative could be considered sufficient, adequate, acceptable and would provide reasonable assurance that the plant's turbine overspeed protection means will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC's regulations.

Additional Westinghouse Response per additional NRC request: (Revision 2)

An ITAAC item has been added to Tier 1 Table 2.4.2-1 which states, “A report exists and concludes that the two turbine electrical overspeed protection systems within the PLS have diverse hardware and software/firmware.”


In addition, as a result of a conference call with the NRC on July 23, 2009, Westinghouse is proposing clarifications be made to Tier 2 DCD subsections 10.2.2.4.1, 10.2.2.4.5, and 10.2.2.5.3. Westinghouse stated in the conference call that both the 110% and 111% overspeed trip systems are not contained in a single controller and that one of the trips is contained in a non-Ovation controller. The commitment to separate these trips into separate, diverse controllers was made after DCD Revision 17 was issued in response to the staff's initial submittal of this RAI.

The DCD changes proposed below show and clarify that the 110% and 111% trip systems have diverse hardware and software/firmware to eliminate common cause failures (CCFs) from rendering the trip functions inoperable. A diagram is provided below to show the system configuration with a non-Ovation controller for the diverse 110% emergency trip system.

Also, the 110% and 111% trip discussions are removed at this time from Section 10.2.2.4.1, 'Speed Control,' for clarity. The term 'speed control' refers to normal turbine control/operation. The 110% and 111% overspeed trips are addressed in subsections 10.2.2.4.5 and 10.2.2.5.3, and were kept in Section 10.2.2.4.1 for DCD Revs 16 and 17 to stay consistent with the Rev 15 “format.”

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)



AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Additional NRC request via 10/9/09 email: (Revision 3)

Regarding the Westinghouse response to RAI-SRP10.2-SBPA-02 R2 (DCP NRC 002647, October 7, 2009), the staff feels that Tier 2 updates should include your diversity design description and the letter's figure. Tier 1 updates appear complete.

Additional Westinghouse Response: (Revision 3)

The above description of the diversity design was reviewed. Additional changes are made in the DCD markup below to complete the Tier 2 description, as follows:

1. The word "separate" was added to Section 10.2.2.5.3, "Overspeed Trip Functions and Mechanisms" to make the portion read "in the separate OA controller."
2. The following sentences were added to the final paragraph of Section 10.2.2.5.3, "Overspeed Trip Functions and Mechanisms":

"The control signals from the two turbine-generator overspeed trip systems are isolated from, and independent of, each other. Each trip is initiated electrically in separate systems. The 110% and 111% trip systems have diverse hardware and software/firmware to eliminate common cause failures (CCFs) from rendering the trip functions inoperable."

3. The figure showing the diversity design provided in Revision 2 of this response is improved and added below as a new DCD Figure 10.2-2, "Emergency Trip System Functional Diagram."

Design Control Document (DCD) Revision: (RAI response revision shown by section)

Modify DCD Tier 1, Section 2.4.2 as shown: (Revision 1, 2)

2.4.2 Main Turbine System

Design Description

The main turbine system (MTS) is designed for electric power production consistent with the capability of the reactor and the reactor coolant system.

The component locations of the MTS are as shown in Table 2.4.2-2.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

1. The functional arrangement of the MTS is as described in the Design Description of this Section 2.4.2.
2.
 - a) Controls exist in the MCR to trip the main turbine-generator.
 - b) The main turbine-generator trips after receiving a signal from the PMS.
 - c) The main turbine-generator trips after receiving a signal from the DAS.
3. The overspeed trips for the AP1000 turbine are set for 110% and 111% ($\pm 1\%$ each). Each trip is initiated electrically in separate systems. The control signals from the two turbine-generator overspeed trip systems are isolated from, and independent of, each other.

Inspections, Tests, Analyses, and Acceptance Criteria

Table 2.4.2-1 specifies the inspections, tests, analyses, and associated acceptance criteria for the MTS.

Table 2.4.2-1 Inspections, Tests, Analyses, and Acceptance Criteria		
Design Commitment	Inspections, Test, Analyses	Acceptance Criteria
1. The functional arrangement of the MTS is as described in the Design Description of this Section 2.4.2.	Inspection of the as-built system will be performed.	The as-built MTS conforms with the functional arrangement as described in the Design Description of this Section 2.4.2.
2.a) Controls exist in the MCR to trip the main turbine-generator.	Testing will be performed on the main turbine-generator using controls in the MCR.	Controls in the MCR operate to trip the main turbine-generator.
2.b) The main turbine-generator trips after receiving a signal from the PMS.	Testing will be performed using real or simulated signals into the PMS.	The main turbine-generator trips after receiving a signal from the PMS.
2.c) The main turbine-generator trips after receiving a signal from the DAS.	Testing will be performed using real or simulated signals into the DAS.	The main turbine-generator trips after receiving a signal from the DAS.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

<p><u>3) The trip signals from the two turbine electrical overspeed protection trip systems within the PLS are isolated from, and independent of, each other.</u></p>	<p><u>i) The system design will be reviewed.</u></p> <p><u>ii) Testing of the as-built system will be performed using simulated signals from the turbine speed sensors.</u></p> <p><u>iii) Inspection will be performed for the existence of a report verifying that the two turbine electrical overspeed protection systems have diverse hardware and software/firmware.</u></p>	<p><u>i) The system design review shows that the trip signals of the two electrical overspeed protection trip systems are isolated from, and independent of, each other.</u></p> <p><u>ii) The main turbine-generator trips after overspeed signals are received from the speed sensors of the 110% emergency electrical overspeed trip system, and, the main turbine-generator trips after overspeed signals are received from the speed sensors of the 111% backup electrical overspeed trip system.</u></p> <p><u>iii) A report exists and concludes that the two electrical overspeed protection systems within the PLS have diverse hardware and software/firmware.</u></p>
---	---	--

Modify Tier 2 Section 10.2.2.4.1 as shown (Revision 2):

10.2.2.4.1 Speed Control (Normal Turbine Operation)

The speed control function of the turbine control and protection system's redundant controller provides speed control and acceleration functions for normal turbine operation. It also provides the backup 111% overspeed protection function as discussed in subsection 10.2.2.5.3. The speed error signal is derived by comparing the desired setpoint speed with the actual speed of the turbine. This error drives an algorithm that positions the control valves at the desired setpoint. Acceleration rates can also be entered by the operator or calculated by the control

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

system in the auto start-up mode. A failure of one speed input generates an alarm. Failure of two or more speed inputs also generates an alarm and trips the turbine.

The speed control function exists in triplicate channels, which include the load (frequency) control function if the main generator breaker is closed. If one channel fails, the lower signal of the remaining two channels is selected by the median value gate (MVG) and fed into the valve positioning control function.

The control system's operator automatic (OA) controller provides the speed control function. At 101% of rated speed the control valves and intercept valves begin to close, but do not trip the turbine.

The speed control function is designed to prevent the operator from holding the turbine speed at a bearing critical or blade resonance point.

Modify Tier 2 Section 10.2.2.4.5 as shown (Revision 2):

10.2.2.4.5 Overspeed Protection

The turbine control and protection system has four functions to protect the turbine against overspeed. The first is the overspeed protection system (OSP), which at 101% of rated speed, begins to close the control and intercept valves as discussed in subsection 10.2.2.4.1. The second and third are the 110% and 111% overspeed trip functions also discussed in subsection 10.2.2.5. The fourth function is the partial load unbalance discussed in subsection 10.2.2.4.4.

Redundancy is built into the overspeed protection system. The failure of a single valve will not disable the trip functions. The overspeed protection components are designed to fail in a safe position. Loss of the hydraulic pressure in the emergency trip system causes a turbine trip. Therefore, damage to the overspeed protection components, results in the closure of the valves and the interruption of steam flow to the turbine.

Quick closure of the steam valves prevents turbine overspeed. Valve closing times are given in Table 10.2-4.

Modify Tier 2 Section 10.2.2.5.3 as shown (Revisions 1, 2, and 3):

10.2.2.5.3 Overspeed Trip Functions and Mechanisms

The overspeed trips for the AP1000 turbine consist of a 110% trip in the emergency trip system (ETS) and a 111% backup trip in the separate OA controller (see Figure 10.2-2). The overspeed trip setpoints are identified in Table 10.2-2. The overspeed protection system will function for all abnormal conditions, including a single failure of any component or subsystem.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

The 110% trip is implemented electronically rather than mechanically as indicated in the review procedure in SRP 10.2, part III-2-C. An independent and redundant backup electrical overspeed trip circuit senses the turbine speed by magnetic pickup and closes all valves associated with speed control at approximately 111% of rated speed.


The 110% ETS trip system has triplicated passive speed sensors separate from the triplicated active speed sensors used in the backup 111% trip. Both trip functions use solenoid valves to drain the emergency trip hydraulic supply. The hydraulic fluid in the trip and overspeed protection control headers is independent of the bearing lubrication system to minimize the potential for contamination of the fluid.

The diverse 110% ETS overspeed protection system combined with the 111% OA overspeed protection function of the control system provide a level of redundancy and diversity at least equivalent to the recommendations for turbine overspeed protection found in III.2 of Standard Review Plan (NUREG-0800) Section 10.2. The control signals from the two turbine-generator overspeed trip systems are isolated from, and independent of, each other. Each trip is initiated electrically in separate systems. The 110% and 111% trip systems have diverse hardware and software/firmware to eliminate common cause failures (CCFs) from rendering the trip functions inoperable. Additionally, the issues and problems with overspeed protection systems identified in NUREG-1275 (Reference 3) have been addressed.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Add new DCD Figure 10.2-2, "Emergency Trip System Functional Diagram"



AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

PRA Revision:

None

Technical Report (TR) Revision:

None