

PMBeCOL PEmails

From: Habib, Donald
Sent: Monday, January 04, 2010 8:22 AM
To: 'Spink, Thomas E'; 'andrea sterdis'; Wes Sparkman; Amy Aughtman
Cc: Comar, Manny; Sebrosky, Joseph; BeCOL Resource
Subject: Draft RAI 4184 - SRP 6.4 Control Room Habitability System for Bellefonte Units 3 and 4
Attachments: RAI 4184.doc

To All:

Attached please find draft RAI 4184. Please contact me within 3 days if a conference call is required for clarification, or the final RAI will be issued.

Thank you

Donald C. Habib
Project Manager
U.S. Nuclear Regulatory Commission
Office of New Reactors, DNRL/NWE1
Room T-6D14
Washington, DC 20555
301-415-1035
dch3@nrc.gov

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 1750

Mail Envelope Properties (E3D0DF334F617344BE38EB00C881B1B303945F8BF4)

Subject: Draft RAI 4184 - SRP 6.4 Control Room Habitability System for Bellefonte Units
3 and 4
Sent Date: 1/4/2010 8:22:09 AM
Received Date: 1/4/2010 8:22:13 AM
From: Habib, Donald

Created By: Donald.Habib@nrc.gov

Recipients:

"Comar, Manny" <Manny.Comar@nrc.gov>
Tracking Status: None
"Sebrosky, Joseph" <Joseph.Sebrosky@nrc.gov>
Tracking Status: None
"BelCol Resource" <BelCol.Resource@nrc.gov>
Tracking Status: None
"Spink, Thomas E" <tespink@tva.gov>
Tracking Status: None
"andrea sterdis" <alsterdis@tva.gov>
Tracking Status: None
"Wes Sparkman" <wasparkm@southernco.com>
Tracking Status: None
"Amy Aughtman" <agaughtm@southernco.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	389	1/4/2010 8:22:13 AM
RAI 4184.doc	29178	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 4184 Revision 0

Bellefonte Units 3 and 4
TVA
Docket No. 52-014 and 52-015
SRP Section: 06.04 - Control Room Habitability System
Application Section: 6.4 - Habitability Systems

QUESTIONS for Containment and Ventilation Branch 1 (AP1000/EPR Projects) (SPCV)

06.04-***

Supplemental RAI to NRC RAI Number: 02.02.03-10 & RLN RAI ID: 2223

1. Credit being taken for the chemical hazard analysis to support Table 6.4-202 in COLA Part 2. FSAR Chapter 6

Do any of the analyses of the chemicals in Table 6.4-202 credit design features, such as an elevated control room intake, to keep the chemical concentration in the control room below the IDLH (Immediately Dangerous to Life and Health) levels? If so, please provide a description of the design features credited in the safety analyses in the FSAR (a simple annotation Table 6.4-202 to acknowledge these design features would be sufficient).