



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 13, 2010

Mr. George H. Gellrich, Vice President
Calvert Cliffs Nuclear Power Plant, LLC
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RE: CALVERT CLIFFS
NUCLEAR POWER PLANT, UNIT NO. 2 - 2009 STEAM GENERATOR TUBE
INSPECTIONS (TAC NO. ME2167)

Dear Mr. Gellrich:

By letter dated August 17, 2009 (Agencywide Document Access and Management System Accession No. ML092360423), Calvert Cliffs Nuclear Power Plant, LLC submitted information summarizing the results of the 2009 steam generator tube inspections performed at Calvert Cliffs Nuclear Power Plant, Unit No. 2.

The NRC staff has reviewed the submitted information and determined that additional information is required in order to complete the evaluation. The staff has prepared the enclosed request for additional information.

Based upon discussions with your staff, we understand that you plan to respond to the enclosure within 45 days from the date of this letter. Please contact me at 301-415-1364 if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Douglas V. Pickett".

Douglas V. Pickett, Senior Project Manager
Plant Licensing Branch 1-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No.: 50-318

Enclosure:
Request for Additional Information

cc w/encl: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION

REGARDING CALVERT CLIFFS NUCLEAR POWER PLANT UNIT NO. 2

STEAM GENERATOR TUBE INSERVICE INSPECTION REPORTS

DOCKET NUMBER 50-318

1. Please discuss the results of the steam drum and U-bend region inspections.
2. The licensee reported that 330 fan bar wear indications were identified in 258 tubes. Please provide the location (e.g., fan bar plus 1 inch), orientation, and measured sizes of each indication.
3. On page 24 and 25 of the August 17, 2009, letter, the licensee reported that the wear depth bounding length is 1.5 inches; please discuss why this is a bounding length for a foreign object.

Enclosure

January 13, 2010

Mr. George H. Gellrich, Vice President
Calvert Cliffs Nuclear Power Plant, LLC
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RE: CALVERT CLIFFS
NUCLEAR POWER PLANT UNIT, NO. 2 - 2009 STEAM GENERATOR TUBE
INSPECTIONS (TAC NO. ME2167)

Dear Mr. Gellrich:

By letter dated August 17, 2009 (Agencywide Document Access and Management System Accession No. ML092360423), Calvert Cliffs Nuclear Power Plant, LLC submitted information summarizing the results of the 2009 steam generator tube inspections performed at Calvert Cliffs Nuclear Power Plant, Unit No. 2.

The NRC staff has reviewed the submitted information and determined that additional information is required in order to complete the evaluation. The staff has prepared the enclosed request for additional information.

Based upon discussions with your staff, we understand that you plan to respond to the enclosure within 45 days from the date of this letter. Please contact me at 301-415-1364 if you have any questions.

Sincerely,

/ra/

Douglas V. Pickett, Senior Project Manager
Plant Licensing Branch 1-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No.: 50-318

Enclosure:
Request for Additional Information

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC LPL1-1 R/F RidsNrrDor|LPL1-1 RidsNrrPMCalvertCliffs
RidsNrrLASLittle RidsOgcMailCenter RidsAcrcAcnwMailCenter
GDentel, RI RidsNrrDciCsgb RidsRgn1MailCenter

ADAMS Accession No.: ML100060085

*by memo

OFFICE	LPL1-1\GE	LPL1-1\PM	LPL1-1\LA	NRR/DCI/CSGB	LPL1-1\BC
NAME	JGall	DPickett	ABaxter for SLittle	RTaylor	NSalgado
DATE	1/5/10	1/12/10	1/12/10	12/14/09*	1/13/10

OFFICIAL RECORD COPY