



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 8, 2010

Mr. George H. Gellrich, Vice President
Calvert Cliffs Nuclear Power Plant, LLC
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT UNIT NOS. 1 AND 2 –
CLOSEOUT OF GENERIC LETTER 2008-01, "MANAGING GAS
ACCUMULATION IN EMERGENCY CORE COOLING, DECAY HEAT
REMOVAL, AND CONTAINMENT SPRAY SYSTEMS" (TAC NOS. MD7807 and
MD7808)

Dear Mr. Gellrich:

On January 11, 2008, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2008-01, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072910759). The stated purpose of GL 2008-01 was (a) to request addressees to submit information to demonstrate that the subject systems are in compliance with the current licensing and design bases and applicable regulatory requirements, and that suitable design, operational, and testing control measures are in place for maintaining this compliance; and (b) to collect the requested information to determine if additional regulatory action is required.

GL 2008-01 requested that licensees provide the following information within 9 months of the date of the GL:

- (a) A description of the results of evaluations that were performed pursuant to requested actions specified in the GL. This description should provide sufficient information to demonstrate that you are or will be in compliance with the quality assurance criteria in Sections III, V, XI, XVI, and XVII of Appendix B to 10 CFR Part 50 and the licensing basis and operating license as those requirements apply to the subject systems;
- (b) A description of all corrective actions, including plant, programmatic, procedure, and licensing basis modifications that you determined were necessary to assure compliance with these regulations; and,
- (c) A statement regarding which corrective actions were completed, the schedule for completing the remaining corrective actions, and the basis for that schedule.

In your letters dated April 11, June 25, October 10, and October 14, 2008, June 12, August 28, and September 28, 2009, (ADAMS Accession Nos. ML081060097, ML081770506, ML082840372, ML082900149, ML091670262, ML092440804 and ML092730178, respectively) you provided information in response to the GL. The NRC staff has reviewed the submitted information and has concluded that for Calvert Cliffs Nuclear Power Plant Unit Nos. 1 and 2,

G. Gellrich

- 2 -

your response to the GL is acceptable. Consequently, your GL response is considered closed and no further information or action is requested of you. Notwithstanding, the NRC's Region I staff may decide to perform (and would contact you to schedule) an inspection using Temporary Instruction (TI) 2515/177, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented or is in the process of acceptably implementing the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01 and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-1364.

Sincerely,

A handwritten signature in black ink that reads "Douglas V. Pickett". The signature is written in a cursive style with a checkmark-like flourish after the first name.

Douglas V. Pickett, Project Manager
Plant Licensing Branch 1-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: Distribution via Listserv

your response to the GL is acceptable. Consequently, your GL response is considered closed and no further information or action is requested of you. Notwithstanding, the NRC's Region I staff may decide to perform (and would contact you to schedule) an inspection using Temporary Instruction (TI) 2515/177, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented or is in the process of acceptably implementing the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01 and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-1364.

Sincerely,

/RA/

Douglas V. Pickett, Project Manager
Plant Licensing Branch 1-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: Distribution via Listserv

Distribution:

PUBLIC	RidsNrrDorLpl1-1 Resource	RidsNrrPMCalvertCliffs
LPL1-1RF	RidsOgcRp Resource	RidsNrrDorIDpr Resource
RidsNrrLASLittle	RidsNrrDssSrxb Resource	RidsRgn1MailCenter

Accession Number: ML100070330

*see memo dated 12/14/09

** concurrence via email

OFFICE	LPL1-1:GE	LPL1-1:PM	LPL1-1:LA	SRXB:BC	LPL1-1/BC
NAME	JGall	DPickett	ABaxter/ for SLittle**	GCranston*	JBoska for NSalgado
DATE	1/06/10	1/08/10	1/08/10	12/14/2009	1/08/10

OFFICIAL RECORD COPY