

PMVogleCOLPEm Resource

From: Habib, Donald
Sent: Monday, December 28, 2009 10:29 AM
To: VogleCOL Resource
Cc: Joshi, Ravindra
Subject: Phone Call Summary Vogle RCOL Chap 12 December 17, 2009
Attachments: Phone Call Summary Vogle RCOL 121709.doc

Hearing Identifier: Vogtle_COL_Public
Email Number: 300

Mail Envelope Properties (E3D0DF334F617344BE38EB00C881B1B303945F84FC)

Subject: Phone Call Summary Vogtle RCOL Chap 12 December 17, 2009
Sent Date: 12/28/2009 10:28:55 AM
Received Date: 12/28/2009 10:29:18 AM
From: Habib, Donald

Created By: Donald.Habib@nrc.gov

Recipients:

"Joshi, Ravindra" <Ravindra.Joshi@nrc.gov>
Tracking Status: None
"VogtleCOL Resource" <VogtleCOL.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	3	12/28/2009 10:29:18 AM
Phone Call Summary Vogtle RCOL 121709.doc	23150	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Subject: Conference Call Summary – December 17, 2009 - Vogtle Electric Generating Plant Units 3 and 4 COLA – Supplemental RAI Responses related to SRP Section 12.3-12.4

MEMORANDUM TO: File (Docket Numbers 52-025, 52-026, Vogtle Units 3 and 4 COLA)

FROM: Donald Habib
Office of New Reactors, Division of New Reactor Licensing
Project Manager, AP1000 Projects Branch 1

On December 17, 2009, NRC staff participated in a telephone conference call with representatives of Vogtle Electric Generating Plant Units 3 and 4 from Southern Nuclear Corporation (SNC) regarding the staff's detailed review of the Vogtle Units 3 and 4 COLA. The purpose of the call was to discuss the applicant responses and submittals pertaining to Chapter 12 of the Vogtle FSAR. The call focused on clarifications relating to the November 20, 2009, supplemental RAI response submitted in response to NRC RAI Letter No. 21 (eRAI Nos. 1748, 1751, and 1752). As a result of the call, SNC agreed to two action items:

RAI 12.03-04-1. For estimating worker doses, the quality assurance procedures applied to TLD processing and evaluation would be examined, and a supplemental RAI response would be submitted.

RAI 12.03-04-2. Information would be provided in a supplemental RAI response pertaining to definitions for the terms "Free Field Dose" and "Annual dose corrected for occupational exposure," as used in reference documents cited in the previous RAI response. This information relates to determining that the ISFSI contribution to construction worker dose is negligible.

The NRC attendees were:
Stuart Bland (contractor)
Duane DeMore (contractor)
Don Habib
Ed Roach

Non-NRC attendees were:

Amy Aughtman (SNC)
Mike Bronson (Bechtel)
Bob Hirmanpour (NuStart)
Mary Hoganson (Tetra Tech)
Karen Patterson (Tetra Tech)
William Smith (SNC)
Wes Sparkman (SNC)