

## PMVogtleCOLPEm Resource

---

**From:** Javorka, Deborah A. [DAJavork@southernco.com]  
**Sent:** Friday, January 08, 2010 2:04 PM  
**To:** Miller, James H., III; Miller, Buzz (Joseph); Gasser, Jeff T.; Jones, David H.; Tynan, Tom E.; Lloyd, Dale M.; Smith, Michael K.; Ajluni, Mark J.; Williams, James D. (Vogtle); Davis, James T.; Giddens, John M.; Moorer, Tom C.; Sparkman, Wesley A.; Aughtman, Amy G.; Sweeney, Brian J.; Pierce, Chuck R.; Reyes, Luis; Akstulewicz, Frank; Joshi, Ravindra; Hughes, Brian; Simms, Tanya; Anderson, Brian; Comar, Manny; Notich, Mark; Cain, Loyd; Harper, Oscar C.; Jackson, S. (MEAG); 'Mr. J.S. Prebula'; 'Mr. R.W. Prunty'; 'Mr. K.B. Allison'; 'Mr. J.M. Oddo'; 'Mr. D.C. Shutt'; 'Mr. E. Cummins'; 'Norm Boyter'; 'Sam Bradley'; 'Mr. R.B. Sisk'; 'Mr. J.L. Whiteman'; 'Mr. D.A. Lindgren (lindg1da@westinghouse.com)'; 'Mr. R.J. Grumbir'; 'Mr. E. Grant'; 'Mr. B. Hirmanpour'; 'neilhaggerty@comcast.net'; 'Ms. K.N. Slays'; 'Mr. P.S. Hastings'  
**Cc:** Williams, Dana M.  
**Subject:** SNC Letter ND-10-0006 - SNC VEGP Units 3&4 Combined License Application Supplemental Information Addressing Bellefonte Units 3 and 4 Safety Evaluation Report Chapter 04, Confirmatory Item 4.4-1  
**Attachments:** ND-10-0006.pdf  
**Importance:** High

An electronic copy of Southern Nuclear's letter, ND-10-0006 dated January 8, 2010 is attached. A hard copy has been transmitted to the NRC Document Control Desk via FedEx. Thanks!

Deborah Javorka  
Southern Nuclear Operating Company  
Nuclear Development / Project Controls  
42 Inverness Center Parkway - Bin B236  
Birmingham, AL 35242  
[dajavork@southernco.com](mailto:dajavork@southernco.com)  
Phone: (205) 992-5187  
Fax: (205) 992-5296

**Hearing Identifier:** Vogtle\_COL\_Public  
**Email Number:** 315

**Mail Envelope Properties** (235FF5C46790104687D2103E55C98F04C1499480)

**Subject:** SNC Letter ND-10-0006 - SNC VEGP Units 3&4 Combined License Application  
Supplemental Information Addressing Bellefonte Units 3 and 4 Safety Evaluation Report Chapter 04,  
Confirmatory Item 4.4-1

**Sent Date:** 1/8/2010 2:04:21 PM

**Received Date:** 1/8/2010 2:05:41 PM

**From:** Javorka, Deborah A.

**Created By:** DAJavork@southernco.com

**Recipients:**

"Williams, Dana M." <DANAWILL@SOUTHERNCO.COM>

Tracking Status: None

"Miller, James H., III" <JHMILLER@southernco.com>

Tracking Status: None

"Miller, Buzz (Joseph)" <JAMILLER@southernco.com>

Tracking Status: None

"Gasser, Jeff T." <JTGASSER@southernco.com>

Tracking Status: None

"Jones, David H." <DAHJONES@southernco.com>

Tracking Status: None

"Tynan, Tom E." <TETYNAN@southernco.com>

Tracking Status: None

"Lloyd, Dale M." <DMLLOYD@southernco.com>

Tracking Status: None

"Smith, Michael K." <MKSmith@southernco.com>

Tracking Status: None

"Ajluni, Mark J." <MJAJLUNI@southernco.com>

Tracking Status: None

"Williams, James D. (Vogtle)" <JADWILLI@southernco.com>

Tracking Status: None

"Davis, James T." <JTDAVIS@southernco.com>

Tracking Status: None

"Giddens, John M." <JMGIDDEN@southernco.com>

Tracking Status: None

"Moorer, Tom C." <TCMOORER@southernco.com>

Tracking Status: None

"Sparkman, Wesley A." <WASPARKM@southernco.com>

Tracking Status: None

"Aughtman, Amy G." <AGAUGHTM@SOUTHERNCO.COM>

Tracking Status: None

"Sweeney, Brian J." <X2SWEENE@southernco.com>

Tracking Status: None

"Pierce, Chuck R." <CRPIERCE@southernco.com>

Tracking Status: None

"Reyes, Luis" <Luis.Reyes@nrc.gov>

Tracking Status: None

"Akstulewicz, Frank" <Frank.Akstulewicz@nrc.gov>

Tracking Status: None

"Joshi, Ravindra" <Ravindra.Joshi@nrc.gov>

Tracking Status: None  
"Hughes, Brian" <Brian.Hughes@nrc.gov>  
Tracking Status: None  
"Simms, Tanya" <Tanya.Simms@nrc.gov>  
Tracking Status: None  
"Anderson, Brian" <Brian.Anderson@nrc.gov>  
Tracking Status: None  
"Comar, Manny" <Manny.Comar@nrc.gov>  
Tracking Status: None  
"Notich, Mark" <Mark.Notich@nrc.gov>  
Tracking Status: None  
"Cain, Loyd" <Loyd.Cain@nrc.gov>  
Tracking Status: None  
"Harper, Oscar C." <OCHARPER@southernco.com>  
Tracking Status: None  
"Jackson, S. (MEAG)" <sjackson@meagpower.org>  
Tracking Status: None  
"Mr. J.S. Prebula" <jprebula@bechtel.com>  
Tracking Status: None  
"Mr. R.W. Prunty" <rwprunty@bechtel.com>  
Tracking Status: None  
"Mr. K.B. Allison" <kenneth.allison@shawgrp.com>  
Tracking Status: None  
"Mr. J.M. Oddo" <john.oddo@shawgrp.com>  
Tracking Status: None  
"Mr. D.C. Shutt" <daniel.shutt@shawgrp.com>  
Tracking Status: None  
"Mr. E. Cummins" <cumminwe@westinghouse.com>  
Tracking Status: None  
"Norm Boyter" <boyternc@westinghouse.com>  
Tracking Status: None  
"Sam Bradley" <bradlesa@westinghouse.com>  
Tracking Status: None  
"Mr. R.B. Sisk" <sisk1rb@westinghouse.com>  
Tracking Status: None  
"Mr. J.L. Whiteman" <whitemjl@westinghouse.com>  
Tracking Status: None  
"Mr. D.A. Lindgren (lindg1da@westinghouse.com)" <lindg1da@westinghouse.com>  
Tracking Status: None  
"Mr. R.J. Grumbir" <rgrumbir@gmail.com>  
Tracking Status: None  
"Mr. E. Grant" <eddie.grant@excelservices.com>  
Tracking Status: None  
"Mr. B. Hirmanpour" <Bob.Hirmanpour@excelservices.com>  
Tracking Status: None  
"neilhaggerty@comcast.net" <neilhaggerty@comcast.net>  
Tracking Status: None  
"Ms. K.N. Slays" <Kim.Slays@duke-energy.com>  
Tracking Status: None  
"Mr. P.S. Hastings" <peter.hastings@duke-energy.com>  
Tracking Status: None

**Post Office:** FMXAPEX81PR.southernco.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	440	1/8/2010 2:05:41 PM

ND-10-0006.pdf

575652

**Options**

**Priority:**

High

**Return Notification:**

No

**Reply Requested:**

No

**Sensitivity:**

Normal

**Expiration Date:**

**Recipients Received:**

**J. A. "Buzz" Miller**  
Executive Vice President  
Nuclear Development

**Southern Nuclear  
Operating Company, Inc.**  
42 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
  
Tel 205.992.5754  
Fax 205.992.6165



**JAN 08 2010**

Docket Nos.: 52-025  
52-026

ND-10-0006

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Units 3 and 4 Combined License Application  
Supplemental Information Addressing Bellefonte Units 3 and 4  
Safety Evaluation Report Chapter 04, Confirmatory Item 4.4-1

Ladies and Gentlemen:

By letter dated March 28, 2008, Southern Nuclear Operating Company (SNC) submitted an application for combined licenses (COLs) for proposed Vogtle Electric Generating Plant (VEGP) Units 3 and 4 to the U.S. Nuclear Regulatory Commission (NRC) for two Westinghouse AP1000 reactor plants, in accordance with 10 CFR Part 52. As a result of the NRC's detailed review of the initial AP1000 Reference COL application (Bellefonte Units 3 and 4), the NRC has written a safety evaluation report (SER) with open items for the subject chapter. VEGP is providing additional information (related to confirmatory item 4.4-1 identified in the SER) as the new Reference COL applicant in the enclosure to this letter.

If you have any questions regarding this letter, please contact Mr. Wes Sparkman at (205) 992-5061 or Ms. Amy Aughtman at (205) 992-5805.

Mr. J. A. (Buzz) Miller states he is an Executive Vice President of Southern Nuclear Operating Company, is authorized to execute this oath on behalf of Southern Nuclear Operating Company and to the best of his knowledge and belief, the facts set forth in this letter are true.

Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY



Joseph A. (Buzz) Miller

Sworn to and subscribed before me this 8<sup>th</sup> day of January, 2010

Notary Public: Gail A. Harts

My commission expires: July 5, 2010

JAM/BJS/dmw

Enclosure: Response to R-COLA SER with Open Items, Chapter 04

cc: Southern Nuclear Operating Company

Mr. J. H. Miller, III, President and CEO (w/o enclosure)  
Mr. J. T. Gasser, Executive Vice President, Nuclear Operations (w/o enclosure)  
Mr. D. H. Jones, Site Vice President, Vogtle 3 & 4 (w/o enclosure)  
Mr. T. E. Tynan, Vice President - Vogtle (w/o enclosure)  
Mr. D. M. Lloyd, Vogtle 3 & 4 Project Support Director (w/o enclosure)  
Mr. M. K. Smith, Technical Support Director (w/o enclosure)  
Mr. C. R. Pierce, AP1000 Licensing Manager  
Mr. M. J. Ajluni, Nuclear Licensing Manager  
Mr. J. D. Williams, Vogtle 3 & 4 Site Support Manager  
Mr. J. T. Davis, Vogtle 3 & 4 Site Licensing Manager  
Mr. W. A. Sparkman, COL Project Engineer  
Document Services RTYPE: AR01.1053  
File AR.01.02.06

Nuclear Regulatory Commission

Mr. L. A. Reyes, Region II Administrator  
Mr. F.M. Akstulewicz, Deputy Director Div. of Safety Systems & Risk Assess. (w/o enclosure)  
Mr. R. G. Joshi, Lead Project Manager of New Reactors  
Ms. T. E. Simms, Project Manager of New Reactors  
Mr. B. C. Anderson, Project Manager of New Reactors  
Mr. M. M. Comar, Project Manager of New Reactors  
Ms. S. Goetz, Project Manager of New Reactors  
Mr. J. M. Sebrosky, Project Manager of New Reactors  
Mr. D. C. Habib, Project Manager of New Reactors  
Ms. D. L. McGovern, Project Manager of New Reactors  
Ms. T. L. Spicher, Project Manager of New Reactors  
Ms. M. A. Sutton, Environmental Project Manager  
Mr. M. D. Notich, Environmental Project Manager  
Mr. L. M. Cain, Senior Resident Inspector of VEGP

Georgia Power Company

Mr. O. C. Harper, IV, Vice President, Resource Planning and Nuclear Development

Oglethorpe Power Corporation

Mr. M. W. Price, Executive Vice President and Chief Operating Officer  
Mr. K. T. Haynes, Director of Contracts and Regulatory Oversight

Municipal Electric Authority of Georgia

Mr. S. M. Jackson, Vice President, Power Supply

Dalton Utilities

Mr. D. Cope, President and Chief Executive Officer

Bechtel Power Corporation

Mr. J. S. Prebula, Project Engineer (w/o enclosure)  
Mr. R. W. Prunty, Licensing Engineer

Tetra Tech NUS, Inc.

Ms. K. K. Patterson, Project Manager

Shaw Stone & Webster, Inc.

Mr. K. B. Allison, Project Manager (w/o enclosure)

Mr. J. M. Oddo, Licensing Manager

Mr. D. C. Shutt, Licensing Engineer

Westinghouse Electric Company, LLC

Mr. W. E. Cummins, Vice President of Regulatory Affairs & Standardization (w/o enclosure)

Mr. N. C. Boyter, Consortium Project Director Vogtle Units 3 & 4 (w/o enclosure)

Mr. S. A. Bradley, Vogtle Project Licensing Manager

Mr. R. B. Sisk, Manager, AP1000 Licensing and Customer Interface

Mr. J. L. Whiteman, Principal Engineer, Licensing & Customer Interface

Mr. D. A. Lindgren, Principal Engineer, AP1000 Licensing and Customer Interface

NuStart Energy

Mr. R. J. Grumbir

Mr. E. R. Grant

Mr. B. Hirmanpour

Mr. N. Haggerty

Ms. K. N. Slays

Other NuStart Energy Associates

Ms. M. C. Kray, NuStart

Mr. S. P. Frantz, Morgan Lewis

Mr. P. S. Hastings, NuStart & Duke Energy

Mr. J. A. Bailey, TVA

Ms. A. L. Sterdis, TVA

Mr. J. P. Berger, EDF

Mr. M. W. Gettler, FP&L

Mr. P. Hinnenkamp, Entergy

Mr. G. D. Miller, PG&N

Mr. M. C. Nolan, Duke Energy

Mr. N. T. Simms, Duke Energy

Mr. G. A. Zinke, NuStart & Entergy

Mr. R. H. Kitchen, PGN

Ms. A. M. Monroe, SCE&G

Mr. T. Beville, DOE/PM



**Southern Nuclear Operating Company**

**ND-10-0006**

**Enclosure**

**Response to R-COLA SER with Open Items**

**Chapter 04**

<u>Confirmatory Item</u>	<u>Response</u>
04.04-01	Standard - See enclosed

  

<u>Attachments / Enclosures</u>	<u>Pages Included</u>
None	

**eRAI Tracking No. 3849**

**NuStart Qb Tracking No. 4023**

**NRC SER CI Number 04.04-01:**

RG 1.133, Revision 1, describes a method acceptable to the NRC staff for implementing regulatory requirements with respect to detecting a potentially safety-related loose part in light-water-cooled reactors during normal operation. The AP1000 design includes a digital metal impact monitoring system, which is a non-safety related system provided for monitoring the reactor coolant system for metallic loose parts. AP1000 DCD Subsection 4.4.6.4 documents the conformance of this monitoring system to RG 1.133. BLN COL FSAR Appendix 1AA documents its conformance to the design aspects described in DCD Subsection 4.4.6.4, and also states it conforms to Regulatory Position C.3a, regarding manual mode of data acquisition for detection of loose parts and Regulatory Position C.6, regarding notification to NRC of confirmation of the presence of a loose part.

The NRC staff noted that RG 1.133, Revision 1, was not included in Revision 0 of FSAR Table 1.9-201 for a cross-reference to the appropriate FSAR section, although an evaluation of compliance with RG 1.133 is provided in Appendix 1AA. In response to Request for Additional Information (RAI) 1-7, the applicant added RG 1.133, Revision 1, to Table 1.9-201, as part of Revision 1 to the FSAR. In addition, the response to RAI 1-7 was supplemented by adding a conformance discussion for regulatory guide positions related to the procedures and training program (positions 4g, 4h, 4i and 4j) in the proposed revision to BLN FSAR Appendix 1AA, "A Conformance with Regulatory Guides." The proposed change to BLN FSAR is acceptable subject to a formal revision to BLN FSAR. Accordingly, this is **Confirmatory Item 4.4-1**. With the conformance of the programmatic and operational aspects of regulatory positions, the staff concludes that the applicant's loose parts detection program will conform to RG 1.133, Revision 1.

**SNC Response:**

The supplemental response to BLN-RAI-LTR-142 request for additional information (RAI) 01-11 provided a revision to the conformance statement in FSAR Appendix 1AA for Regulatory Guide 1.133, including an exception to Position C.6. However, following that letter, Regulatory Guide 1.16 (which is referenced in position C.6 of Regulatory Guide 1.133) was withdrawn by the NRC. Thus, COLA Part 2, FSAR Chapter 1, Appendix 1AA will be revised to include the exception due to the withdrawal of Regulatory Guide 1.16 and provide the reporting alternative to be used. The FSAR will be revised as shown in the COL Applications Revisions section below.

This response is expected to be STANDARD for the S-COLAs.

**Associated VEGP COL Application Revisions:**

COLA Part 2, FSAR Chapter 1, Appendix 1AA, Regulatory Guide 1.133, position C.6, will be revised to read:

C.6	Exception	Regulatory Guide 1.16 has been withdrawn. Event reporting is performed in accordance with 10 CFR 50.72 and 50.73 utilizing the guidance of NUREG-1022.
-----	-----------	--------------------------------------------------------------------------------------------------------------------------------------------------------

**ASSOCIATED ATTACHMENTS/ENCLOSURES:**

None